



Performance Data Sheet according to EU Regulation 2015/1095

SEPR Declaration Model: LH114E/4DES-5Y

Refrigerant: R134a

Item	Symbol*	Value		Unit
Evaporating temperature	t	-10	-35	°C
Annual electricity consumption	Q	16839		kWh/a
Seasonal Energy Performance Ratio	SEPR	3,27		

Point A: Parameters at full load and ambient temperature 32°C

Rated cooling capacity	P _A	8,96		kW
Rated power input	D _A	3,72		kW
Rated COP	COP_A	2,41		

Point B: Parameters at part load and ambient temperature 25°C

Declared cooling capacity	P _B	9,81		kW
Declared power input	D _B	3,50		kW
Declared COP	COP_B	2,80		

Point C: Parameters at part load and ambient temperature 15°C

Declared cooling capacity	P _C	11,00		kW
Declared power input	D _C	3,12		kW
Declared COP	COP_C	3,52		

Point D: Parameters at part load and ambient temperature 5°C

Declared cooling capacity	P _D	11,98		kW
Declared power input	D _D	2,76		kW
Declared COP	COP_D	4,33		

Point E: Parameters at full load and ambient temperature 43°C (information only)

Declared cooling capacity	P _E	7,61		kW
Declared power input	D _E	3,99		kW
Declared COP	COP_E	1,91		

Other items

Capacity control		—		
Reference temperature		Dew point temp.		
Suction gas temperature	toh	20°C		
Power voltage	Net	400V/50Hz		
Coefficient of degradation for units w/o capacity control**	Cdc	0,25		

Additional document: [Declaration of Conformity AC-500](#)

Contact details:

BITZER Kühlmaschinenbau GmbH
Peter-Schaufler-Platz 1
71065 Sindelfingen
Deutschland
Tel +49 (0) 70 31 932-0
Fax +49 (0) 70 31 932-147
E-Mail: bitzer@bitzer.de
Internet: www.bitzer.de

* Symbols taken from english version of the Regulation 2015/1095

** Since condensing units are non functional systems Cdc can not be determined by test. For this reason the default degradation coefficient Cdc (0.25) has to be applied according to EN 13215, Annex A.



Performance Data Sheet according to EU Regulation 2015/1095

SEPR Declaration Model: LH114E/4DES-5Y

Refrigerant: R404A

Item	Symbol*	Value		Unit
Evaporating temperature	t	-10	-35	°C
Annual electricity consumption	Q	28157	20967	kWh/a
Seasonal Energy Performance Ratio	SEPR	3,22	1,76	

Point A: Parameters at full load and ambient temperature 32°C

Rated cooling capacity	P _A	14,73	4,96	kW
Rated power input	D _A	6,62	3,84	kW
Rated COP	COP_A	2,23	1,29	

Point B: Parameters at part load and ambient temperature 25°C

Declared cooling capacity	P _B	16,39	5,59	kW
Declared power input	D _B	6,19	3,74	kW
Declared COP	COP_B	2,65	1,50	

Point C: Parameters at part load and ambient temperature 15°C

Declared cooling capacity	P _C	18,71	6,48	kW
Declared power input	D _C	5,48	3,53	kW
Declared COP	COP_C	3,42	1,84	

Point D: Parameters at part load and ambient temperature 5°C

Declared cooling capacity	P _D	21,0	7,34	kW
Declared power input	D _D	4,66	3,25	kW
Declared COP	COP_D	4,49	2,26	

Point E: Parameters at full load and ambient temperature 43°C (information only)

Declared cooling capacity	P _E	12,08	3,95	kW
Declared power input	D _E	7,17	3,92	kW
Declared COP	COP_E	1,68	1,01	

Other items

Capacity control	—		
Reference temperature	Dew point temp.		
Suction gas temperature	toh	20°C	
Power voltage	Net	400V/50Hz	
Coefficient of degradation for units w/o capacity control**	Cdc	0,25	

Additional document: [Declaration of Conformity AC-500](#)

Contact details:

BITZER Kühlmaschinenbau GmbH
Peter-Schaufler-Platz 1
71065 Sindelfingen
Deutschland
Tel +49 (0) 70 31 932-0
Fax +49 (0) 70 31 932-147
E-Mail: bitzer@bitzer.de
Internet: www.bitzer.de

* Symbols taken from english version of the Regulation 2015/1095

** Since condensing units are non functional systems Cdc can not be determined by test. For this reason the default degradation coefficient Cdc (0.25) has to be applied according to EN 13215, Annex A.



Performance Data Sheet according to EU Regulation 2015/1095

SEPR Declaration Model: LH114E/4DES-5Y

Refrigerant: R407A

Condensing unit with the selected refrigerant at low temperature application (LT) is only intended for deliveries outside the EU. For EU suitable condensing units, see Declaration of Conformity AC-500.

Item	Symbol*	Value	Unit
Evaporating temperature	t	-10	°C
Annual electricity consumption	Q	25245	kWh/a
Seasonal Energy Performance Ratio	SEPR	3,14	

Point A: Parameters at full load and ambient temperature 32°C

Rated cooling capacity	P _A	12,88	kW
Rated power input	D _A	5,78	kW
Rated COP	COP_A	2,23	

Point B: Parameters at part load and ambient temperature 25°C

Declared cooling capacity	P _B	14,28	kW
Declared power input	D _B	5,45	kW
Declared COP	COP_B	2,62	

Point C: Parameters at part load and ambient temperature 15°C

Declared cooling capacity	P _C	16,28	kW
Declared power input	D _C	4,88	kW
Declared COP	COP_C	3,33	

Point D: Parameters at part load and ambient temperature 5°C

Declared cooling capacity	P _D	18,25	kW
Declared power input	D _D	4,21	kW
Declared COP	COP_D	4,33	

Point E: Parameters at full load and ambient temperature 43°C (information only)

Declared cooling capacity	P _E	10,72	kW
Declared power input	D _E	6,19	kW
Declared COP	COP_E	1,73	

Other items

Capacity control	—		
Reference temperature	Dew point temp.		
Suction gas temperature	toh	20°C	
Power voltage	Net	400V/50Hz	
Coefficient of degradation for units w/o capacity control**	Cdc	0,25	

Additional document: [Declaration of Conformity AC-500](#)

Contact details:

BITZER Kühlmaschinenbau GmbH
Peter-Schaufler-Platz 1
71065 Sindelfingen
Deutschland
Tel +49 (0) 70 31 932-0
Fax +49 (0) 70 31 932-147
E-Mail: bitzer@bitzer.de
Internet: www.bitzer.de

* Symbols taken from english version of the Regulation 2015/1095

** Since condensing units are non functional systems Cdc can not be determined by test. For this reason the default degradation coefficient Cdc (0.25) has to be applied according to EN 13215, Annex A.



Performance Data Sheet according to EU Regulation 2015/1095

SEPR Declaration Model: LH114E/4DES-5Y

Refrigerant: R407C

Item	Symbol*	Value		Unit
Evaporating temperature	t	-10	-35	°C
Annual electricity consumption	Q	24045		kWh/a
Seasonal Energy Performance Ratio	SEPR	3,14		

Point A: Parameters at full load and ambient temperature 32°C

Rated cooling capacity	P _A	12,29		kW
Rated power input	D _A	5,43		kW
Rated COP	COP_A	2,26		

Point B: Parameters at part load and ambient temperature 25°C

Declared cooling capacity	P _B	13,57		kW
Declared power input	D _B	5,13		kW
Declared COP	COP_B	2,65		

Point C: Parameters at part load and ambient temperature 15°C

Declared cooling capacity	P _C	15,38		kW
Declared power input	D _C	4,61		kW
Declared COP	COP_C	3,34		

Point D: Parameters at part load and ambient temperature 5°C

Declared cooling capacity	P _D	17,16		kW
Declared power input	D _D	3,99		kW
Declared COP	COP_D	4,30		

Point E: Parameters at full load and ambient temperature 43°C (information only)

Declared cooling capacity	P _E	10,26		kW
Declared power input	D _E	5,77		kW
Declared COP	COP_E	1,78		

Other items

Capacity control		—		
Reference temperature		Dew point temp.		
Suction gas temperature	toh	20°C		
Power voltage	Net	400V/50Hz		
Coefficient of degradation for units w/o capacity control**	Cdc	0,25		

Additional document: [Declaration of Conformity AC-500](#)

Contact details:

BITZER Kühlmaschinenbau GmbH
Peter-Schaufler-Platz 1
71065 Sindelfingen
Deutschland
Tel +49 (0) 70 31 932-0
Fax +49 (0) 70 31 932-147
E-Mail: bitzer@bitzer.de
Internet: www.bitzer.de

* Symbols taken from english version of the Regulation 2015/1095

** Since condensing units are non functional systems Cdc can not be determined by test. For this reason the default degradation coefficient Cdc (0.25) has to be applied according to EN 13215, Annex A.



Performance Data Sheet according to EU Regulation 2015/1095

SEPR Declaration Model: LH114E/4DES-5Y

Refrigerant: R407F

Condensing unit with the selected refrigerant at low temperature application (LT) is only intended for deliveries outside the EU. For EU suitable condensing units, see Declaration of Conformity AC-500.

Item	Symbol*	Value	Unit
Evaporating temperature	t	-10	°C
Annual electricity consumption	Q	26844	kWh/a
Seasonal Energy Performance Ratio	SEPR	3,12	

Point A: Parameters at full load and ambient temperature 32°C

Rated cooling capacity	P _A	13,61	kW
Rated power input	D _A	6,13	kW
Rated COP	COP _A	2,22	

Point B: Parameters at part load and ambient temperature 25°C

Declared cooling capacity	P _B	15,02	kW
Declared power input	D _B	5,77	kW
Declared COP	COP _B	2,60	

Point C: Parameters at part load and ambient temperature 15°C

Declared cooling capacity	P _C	17,04	kW
Declared power input	D _C	5,15	kW
Declared COP	COP _C	3,31	

Point D: Parameters at part load and ambient temperature 5°C

Declared cooling capacity	P _D	19,04	kW
Declared power input	D _D	4,43	kW
Declared COP	COP _D	4,30	

Point E: Parameters at full load and ambient temperature 43°C (information only)

Declared cooling capacity	P _E	11,43	kW
Declared power input	D _E	6,58	kW
Declared COP	COP _E	1,74	

Other items

Capacity control		—	
Reference temperature		Dew point temp.	
Suction gas temperature	toh	20°C	
Power voltage	Net	400V/50Hz	
Coefficient of degradation for units w/o capacity control**	Cdc	0,25	

Additional document: [Declaration of Conformity AC-500](#)

Contact details:

BITZER Kühlmaschinenbau GmbH
Peter-Schaufler-Platz 1
71065 Sindelfingen
Deutschland
Tel +49 (0) 70 31 932-0
Fax +49 (0) 70 31 932-147
E-Mail: bitzer@bitzer.de
Internet: www.bitzer.de

* Symbols taken from english version of the Regulation 2015/1095

** Since condensing units are non functional systems Cdc can not be determined by test. For this reason the default degradation coefficient Cdc (0.25) has to be applied according to EN 13215, Annex A.



Performance Data Sheet according to EU Regulation 2015/1095

SEPR Declaration Model: LH114E/4DES-5Y

Refrigerant: R454C

Item	Symbol*	Value		Unit
Evaporating temperature	t	-10	-35	°C
Annual electricity consumption	Q	23697	16462	kWh/a
Seasonal Energy Performance Ratio	SEPR	3,05	1,49	

Point A: Parameters at full load and ambient temperature 32°C

Rated cooling capacity	P _A	11,78	3,30	kW
Rated power input	D _A	5,40	2,88	kW
Rated COP	COP_A	2,18	1,15	

Point B: Parameters at part load and ambient temperature 25°C

Declared cooling capacity	P _B	13,07	3,81	kW
Declared power input	D _B	5,10	2,89	kW
Declared COP	COP_B	2,56	1,32	

Point C: Parameters at part load and ambient temperature 15°C

Declared cooling capacity	P _C	14,92	4,54	kW
Declared power input	D _C	4,59	2,85	kW
Declared COP	COP_C	3,25	1,59	

Point D: Parameters at part load and ambient temperature 5°C

Declared cooling capacity	P _D	16,73	5,18	kW
Declared power input	D _D	3,98	2,75	kW
Declared COP	COP_D	4,20	1,88	

Point E: Parameters at full load and ambient temperature 43°C (information only)

Declared cooling capacity	P _E	9,77	2,53	kW
Declared power input	D _E	5,77	2,81	kW
Declared COP	COP_E	1,69	0,90	

Other items

Capacity control	—		
Reference temperature	Dew point temp.		
Suction gas temperature	toh	20°C	
Power voltage	Net	400V/50Hz	
Coefficient of degradation for units w/o capacity control**	Cdc	0,25	

Additional document: [Declaration of Conformity AC-500](#)

Contact details:

BITZER Kühlmaschinenbau GmbH
Peter-Schaufler-Platz 1
71065 Sindelfingen
Deutschland
Tel +49 (0) 70 31 932-0
Fax +49 (0) 70 31 932-147
E-Mail: bitzer@bitzer.de
Internet: www.bitzer.de

* Symbols taken from english version of the Regulation 2015/1095

** Since condensing units are non functional systems Cdc can not be determined by test. For this reason the default degradation coefficient Cdc (0.25) has to be applied according to EN 13215, Annex A.



Performance Data Sheet according to EU Regulation 2015/1095

SEPR Declaration Model: LH114E/4DES-5Y

Refrigerant: R455A

Condensing unit with the selected refrigerant at low temperature application (LT) is only intended for deliveries outside the EU. For EU suitable condensing units, see Declaration of Conformity AC-500.

Item	Symbol*	Value	Unit
Evaporating temperature	t	-10	°C
Annual electricity consumption	Q	26282	kWh/a
Seasonal Energy Performance Ratio	SEPR	2,69	

Point A: Parameters at full load and ambient temperature 32°C

Rated cooling capacity	P _A	11,52	kW
Rated power input	D _A	5,92	kW
Rated COP	COP_A	1,95	

Point B: Parameters at part load and ambient temperature 25°C

Declared cooling capacity	P _B	12,88	kW
Declared power input	D _B	5,64	kW
Declared COP	COP_B	2,28	

Point C: Parameters at part load and ambient temperature 15°C

Declared cooling capacity	P _C	14,85	kW
Declared power input	D _C	5,15	kW
Declared COP	COP_C	2,88	

Point D: Parameters at part load and ambient temperature 5°C

Declared cooling capacity	P _D	16,81	kW
Declared power input	D _D	4,55	kW
Declared COP	COP_D	3,69	

Point E: Parameters at full load and ambient temperature 43°C (information only)

Declared cooling capacity	P _E	9,40	kW
Declared power input	D _E	6,24	kW
Declared COP	COP_E	1,51	

Other items

Capacity control		—	
Reference temperature		Dew point temp.	
Suction gas temperature	toh	20°C	
Power voltage	Net	400V/50Hz	
Coefficient of degradation for units w/o capacity control**	Cdc	0,25	

Additional document: [Declaration of Conformity AC-500](#)

Contact details:

BITZER Kühlmaschinenbau GmbH
 Peter-Schaufler-Platz 1
 71065 Sindelfingen
 Deutschland
 Tel +49 (0) 70 31 932-0
 Fax +49 (0) 70 31 932-147
 E-Mail: bitzer@bitzer.de
 Internet: www.bitzer.de

* Symbols taken from english version of the Regulation 2015/1095

** Since condensing units are non functional systems Cdc can not be determined by test. For this reason the default degradation coefficient Cdc (0.25) has to be applied according to EN 13215, Annex A.



Performance Data Sheet according to EU Regulation 2015/1095

SEPR Declaration Model: LH114E/4DES-5Y

Refrigerant: R507A

Item	Symbol*	Value		Unit
Evaporating temperature	t	-10	-35	°C
Annual electricity consumption	Q	28212	20946	kWh/a
Seasonal Energy Performance Ratio	SEPR	3,29	1,84	

Point A: Parameters at full load and ambient temperature 32°C

Rated cooling capacity	P _A	15,11	5,18	kW
Rated power input	D _A	6,63	3,84	kW
Rated COP	COP_A	2,28	1,35	

Point B: Parameters at part load and ambient temperature 25°C

Declared cooling capacity	P _B	16,83	5,85	kW
Declared power input	D _B	6,20	3,74	kW
Declared COP	COP_B	2,71	1,57	

Point C: Parameters at part load and ambient temperature 15°C

Declared cooling capacity	P _C	19,24	6,79	kW
Declared power input	D _C	5,50	3,53	kW
Declared COP	COP_C	3,50	1,92	

Point D: Parameters at part load and ambient temperature 5°C

Declared cooling capacity	P _D	21,6	7,70	kW
Declared power input	D _D	4,70	3,25	kW
Declared COP	COP_D	4,60	2,37	

Point E: Parameters at full load and ambient temperature 43°C (information only)

Declared cooling capacity	P _E	12,34	4,13	kW
Declared power input	D _E	7,18	3,92	kW
Declared COP	COP_E	1,72	1,05	

Other items

Capacity control		—		
Reference temperature		Dew point temp.		
Suction gas temperature	toh	20°C		
Power voltage	Net	400V/50Hz		
Coefficient of degradation for units w/o capacity control**	Cdc	0,25		

Additional document: [Declaration of Conformity AC-500](#)

Contact details:

BITZER Kühlmaschinenbau GmbH
Peter-Schaufler-Platz 1
71065 Sindelfingen
Deutschland
Tel +49 (0) 70 31 932-0
Fax +49 (0) 70 31 932-147
E-Mail: bitzer@bitzer.de
Internet: www.bitzer.de

* Symbols taken from english version of the Regulation 2015/1095

** Since condensing units are non functional systems Cdc can not be determined by test. For this reason the default degradation coefficient Cdc (0.25) has to be applied according to EN 13215, Annex A.



Performance Data Sheet according to EU Regulation 2015/1095

SEPR Declaration Model: LH114E/4DES-5Y

Refrigerant: R448A

Condensing unit with the selected refrigerant at low temperature application (LT) is only intended for deliveries outside the EU. For EU suitable condensing units, see Declaration of Conformity AC-500.

Item	Symbol*	Value	Unit
Evaporating temperature	t	-10	°C
Annual electricity consumption	Q	26067	kWh/a
Seasonal Energy Performance Ratio	SEPR	3,14	

Point A: Parameters at full load and ambient temperature 32°C

Rated cooling capacity	P _A	13,32	kW
Rated power input	D _A	5,98	kW
Rated COP	COP _A	2,23	

Point B: Parameters at part load and ambient temperature 25°C

Declared cooling capacity	P _B	14,73	kW
Declared power input	D _B	5,62	kW
Declared COP	COP _B	2,62	

Point C: Parameters at part load and ambient temperature 15°C

Declared cooling capacity	P _C	16,76	kW
Declared power input	D _C	5,02	kW
Declared COP	COP _C	3,34	

Point D: Parameters at part load and ambient temperature 5°C

Declared cooling capacity	P _D	18,74	kW
Declared power input	D _D	4,32	kW
Declared COP	COP _D	4,34	

Point E: Parameters at full load and ambient temperature 43°C (information only)

Declared cooling capacity	P _E	11,13	kW
Declared power input	D _E	6,42	kW
Declared COP	COP _E	1,73	

Other items

Capacity control		—	
Reference temperature		Dew point temp.	
Suction gas temperature	toh	20°C	
Power voltage	Net	400V/50Hz	
Coefficient of degradation for units w/o capacity control**	Cdc	0,25	

Additional document: [Declaration of Conformity AC-500](#)

Contact details:

BITZER Kühlmaschinenbau GmbH
Peter-Schaufler-Platz 1
71065 Sindelfingen
Deutschland
Tel +49 (0) 70 31 932-0
Fax +49 (0) 70 31 932-147
E-Mail: bitzer@bitzer.de
Internet: www.bitzer.de

* Symbols taken from english version of the Regulation 2015/1095

** Since condensing units are non functional systems Cdc can not be determined by test. For this reason the default degradation coefficient Cdc (0.25) has to be applied according to EN 13215, Annex A.



Performance Data Sheet according to EU Regulation 2015/1095

SEPR Declaration Model: LH114E/4DES-5Y

Refrigerant: R449A

Condensing unit with the selected refrigerant at low temperature application (LT) is only intended for deliveries outside the EU. For EU suitable condensing units, see Declaration of Conformity AC-500.

Item	Symbol*	Value	Unit
Evaporating temperature	t	-10	°C
Annual electricity consumption	Q	26029	kWh/a
Seasonal Energy Performance Ratio	SEPR	3,13	

Point A: Parameters at full load and ambient temperature 32°C

Rated cooling capacity	P _A	13,26	kW
Rated power input	D _A	5,98	kW
Rated COP	COP _A	2,22	

Point B: Parameters at part load and ambient temperature 25°C

Declared cooling capacity	P _B	14,68	kW
Declared power input	D _B	5,62	kW
Declared COP	COP _B	2,61	

Point C: Parameters at part load and ambient temperature 15°C

Declared cooling capacity	P _C	16,71	kW
Declared power input	D _C	5,02	kW
Declared COP	COP _C	3,33	

Point D: Parameters at part load and ambient temperature 5°C

Declared cooling capacity	P _D	18,70	kW
Declared power input	D _D	4,32	kW
Declared COP	COP _D	4,33	

Point E: Parameters at full load and ambient temperature 43°C (information only)

Declared cooling capacity	P _E	11,07	kW
Declared power input	D _E	6,42	kW
Declared COP	COP _E	1,73	

Other items

Capacity control		—	
Reference temperature		Dew point temp.	
Suction gas temperature	toh	20°C	
Power voltage	Net	400V/50Hz	
Coefficient of degradation for units w/o capacity control**	Cdc	0,25	

Additional document: [Declaration of Conformity AC-500](#)

Contact details:

BITZER Kühlmaschinenbau GmbH
Peter-Schaufler-Platz 1
71065 Sindelfingen
Deutschland
Tel +49 (0) 70 31 932-0
Fax +49 (0) 70 31 932-147
E-Mail: bitzer@bitzer.de
Internet: www.bitzer.de

* Symbols taken from english version of the Regulation 2015/1095

** Since condensing units are non functional systems Cdc can not be determined by test. For this reason the default degradation coefficient Cdc (0.25) has to be applied according to EN 13215, Annex A.



Performance Data Sheet according to EU Regulation 2015/1095

SEPR Declaration Model: LH114E/4DES-5Y

Refrigerant: R450A

Item	Symbol*	Value		Unit
Evaporating temperature	t	-10	-35	°C
Annual electricity consumption	Q	15324		kWh/a
Seasonal Energy Performance Ratio	SEPR	3,15		

Point A: Parameters at full load and ambient temperature 32°C

Rated cooling capacity	P _A	7,84		kW
Rated power input	D _A	3,36		kW
Rated COP	COP_A	2,33		

Point B: Parameters at part load and ambient temperature 25°C

Declared cooling capacity	P _B	8,60		kW
Declared power input	D _B	3,16		kW
Declared COP	COP_B	2,72		

Point C: Parameters at part load and ambient temperature 15°C

Declared cooling capacity	P _C	9,66		kW
Declared power input	D _C	2,83		kW
Declared COP	COP_C	3,41		

Point D: Parameters at part load and ambient temperature 5°C

Declared cooling capacity	P _D	10,47		kW
Declared power input	D _D	2,54		kW
Declared COP	COP_D	4,12		

Point E: Parameters at full load and ambient temperature 43°C (information only)

Declared cooling capacity	P _E	6,64		kW
Declared power input	D _E	3,61		kW
Declared COP	COP_E	1,84		

Other items

Capacity control		—		
Reference temperature		Dew point temp.		
Suction gas temperature	toh	20°C		
Power voltage	Net	400V/50Hz		
Coefficient of degradation for units w/o capacity control**	Cdc	0,25		

Additional document: [Declaration of Conformity AC-500](#)

Contact details:

BITZER Kühlmaschinenbau GmbH
Peter-Schaufler-Platz 1
71065 Sindelfingen
Deutschland
Tel +49 (0) 70 31 932-0
Fax +49 (0) 70 31 932-147
E-Mail: bitzer@bitzer.de
Internet: www.bitzer.de

* Symbols taken from english version of the Regulation 2015/1095

** Since condensing units are non functional systems Cdc can not be determined by test. For this reason the default degradation coefficient Cdc (0.25) has to be applied according to EN 13215, Annex A.



Performance Data Sheet according to EU Regulation 2015/1095

SEPR Declaration Model: LH114E/4DES-5Y

Refrigerant: R513A

Item	Symbol*	Value		Unit
Evaporating temperature	t	-10	-35	°C
Annual electricity consumption	Q	17510		kWh/a
Seasonal Energy Performance Ratio	SEPR	3,34		

Point A: Parameters at full load and ambient temperature 32°C

Rated cooling capacity	P _A	9,50		kW
Rated power input	D _A	3,91		kW
Rated COP	COP_A	2,43		

Point B: Parameters at part load and ambient temperature 25°C

Declared cooling capacity	P _B	10,45		kW
Declared power input	D _B	3,68		kW
Declared COP	COP_B	2,84		

Point C: Parameters at part load and ambient temperature 15°C

Declared cooling capacity	P _C	11,76		kW
Declared power input	D _C	3,29		kW
Declared COP	COP_C	3,58		

Point D: Parameters at part load and ambient temperature 5°C

Declared cooling capacity	P _D	12,92		kW
Declared power input	D _D	2,89		kW
Declared COP	COP_D	4,47		

Point E: Parameters at full load and ambient temperature 43°C (information only)

Declared cooling capacity	P _E	7,99		kW
Declared power input	D _E	4,19		kW
Declared COP	COP_E	1,90		

Other items

Capacity control		—		
Reference temperature		Dew point temp.		
Suction gas temperature	toh	20°C		
Power voltage	Net	400V/50Hz		
Coefficient of degradation for units w/o capacity control**	Cdc	0,25		

Additional document: [Declaration of Conformity AC-500](#)

Contact details:

BITZER Kühlmaschinenbau GmbH
Peter-Schaufler-Platz 1
71065 Sindelfingen
Deutschland
Tel +49 (0) 70 31 932-0
Fax +49 (0) 70 31 932-147
E-Mail: bitzer@bitzer.de
Internet: www.bitzer.de

* Symbols taken from english version of the Regulation 2015/1095

** Since condensing units are non functional systems Cdc can not be determined by test. For this reason the default degradation coefficient Cdc (0.25) has to be applied according to EN 13215, Annex A.



Performance Data Sheet according to EU Regulation 2015/1095

SEPR Declaration Model: LH114E/4DES-5Y

Refrigerant: R1234yf

Item	Symbol*	Value		Unit
Evaporating temperature	t	-10	-35	°C
Annual electricity consumption	Q	16608		kWh/a
Seasonal Energy Performance Ratio	SEPR	3,30		

Point A: Parameters at full load and ambient temperature 32°C

Rated cooling capacity	P _A	8,91		kW
Rated power input	D _A	3,74		kW
Rated COP	COP_A	2,38		

Point B: Parameters at part load and ambient temperature 25°C

Declared cooling capacity	P _B	9,82		kW
Declared power input	D _B	3,51		kW
Declared COP	COP_B	2,80		

Point C: Parameters at part load and ambient temperature 15°C

Declared cooling capacity	P _C	11,11		kW
Declared power input	D _C	3,13		kW
Declared COP	COP_C	3,55		

Point D: Parameters at part load and ambient temperature 5°C

Declared cooling capacity	P _D	12,22		kW
Declared power input	D _D	2,76		kW
Declared COP	COP_D	4,42		

Point E: Parameters at full load and ambient temperature 43°C (information only)

Declared cooling capacity	P _E	7,47		kW
Declared power input	D _E	4,03		kW
Declared COP	COP_E	1,85		

Other items

Capacity control		—		
Reference temperature		Dew point temp.		
Suction gas temperature	toh	20°C		
Power voltage	Net	400V/50Hz		
Coefficient of degradation for units w/o capacity control**	Cdc	0,25		

Additional document: [Declaration of Conformity AC-500](#)

Contact details:

BITZER Kühlmaschinenbau GmbH
Peter-Schaufler-Platz 1
71065 Sindelfingen
Deutschland
Tel +49 (0) 70 31 932-0
Fax +49 (0) 70 31 932-147
E-Mail: bitzer@bitzer.de
Internet: www.bitzer.de

* Symbols taken from english version of the Regulation 2015/1095

** Since condensing units are non functional systems Cdc can not be determined by test. For this reason the default degradation coefficient Cdc (0.25) has to be applied according to EN 13215, Annex A.



Performance Data Sheet according to EU Regulation 2015/1095

SEPR Declaration Model: LH114E/4DES-5Y

Refrigerant: R1234ze

Item	Symbol*	Value		Unit
Evaporating temperature	t	-10	-35	°C
Annual electricity consumption	Q	13681		kWh/a
Seasonal Energy Performance Ratio	SEPR	2,96		

Point A: Parameters at full load and ambient temperature 32°C

Rated cooling capacity	P _A	6,59		kW
Rated power input	D _A	2,89		kW
Rated COP	COP_A	2,28		

Point B: Parameters at part load and ambient temperature 25°C

Declared cooling capacity	P _B	7,19		kW
Declared power input	D _B	2,72		kW
Declared COP	COP_B	2,64		

Point C: Parameters at part load and ambient temperature 15°C

Declared cooling capacity	P _C	8,04		kW
Declared power input	D _C	2,44		kW
Declared COP	COP_C	3,29		

Point D: Parameters at part load and ambient temperature 5°C

Declared cooling capacity	P _D	8,47		kW
Declared power input	D _D	2,30		kW
Declared COP	COP_D	3,69		

Point E: Parameters at full load and ambient temperature 43°C (information only)

Declared cooling capacity	P _E	5,63		kW
Declared power input	D _E	3,10		kW
Declared COP	COP_E	1,82		

Other items

Capacity control		—		
Reference temperature		Dew point temp.		
Suction gas temperature	toh	20°C		
Power voltage	Net	400V/50Hz		
Coefficient of degradation for units w/o capacity control**	Cdc	0,25		

Additional document: [Declaration of Conformity AC-500](#)

Contact details:

BITZER Kühlmaschinenbau GmbH
Peter-Schaufler-Platz 1
71065 Sindelfingen
Deutschland
Tel +49 (0) 70 31 932-0
Fax +49 (0) 70 31 932-147
E-Mail: bitzer@bitzer.de
Internet: www.bitzer.de

* Symbols taken from english version of the Regulation 2015/1095

** Since condensing units are non functional systems Cdc can not be determined by test. For this reason the default degradation coefficient Cdc (0.25) has to be applied according to EN 13215, Annex A.