



Performance Data Sheet according to EU Regulation 2015/1095

SEPR Declaration Model: LH124E/4CES-6Y

Refrigerant: R134a

Item	Symbol*	Value		Unit
Evaporating temperature	t	-10	-35	°C
Annual electricity consumption	Q	19951		kWh/a
Seasonal Energy Performance Ratio	SEPR	3,39		

Point A: Parameters at full load and ambient temperature 32°C

Rated cooling capacity	P _A	11,01		kW
Rated power input	D _A	4,45		kW
Rated COP	COP_A	2,48		

Point B: Parameters at part load and ambient temperature 25°C

Declared cooling capacity	P _B	12,01		kW
Declared power input	D _B	4,17		kW
Declared COP	COP_B	2,88		

Point C: Parameters at part load and ambient temperature 15°C

Declared cooling capacity	P _C	13,41		kW
Declared power input	D _C	3,70		kW
Declared COP	COP_C	3,63		

Point D: Parameters at part load and ambient temperature 5°C

Declared cooling capacity	P _D	14,65		kW
Declared power input	D _D	3,23		kW
Declared COP	COP_D	4,54		

Point E: Parameters at full load and ambient temperature 43°C (information only)

Declared cooling capacity	P _E	9,43		kW
Declared power input	D _E	4,81		kW
Declared COP	COP_E	1,96		

Other items

Capacity control		—		
Reference temperature		Dew point temp.		
Suction gas temperature	toh	20°C		
Power voltage	Net	400V/50Hz		
Coefficient of degradation for units w/o capacity control**	Cdc	0,25		

Additional document: [Declaration of Conformity AC-500](#)

Contact details:

BITZER Kühlmaschinenbau GmbH
Peter-Schaufler-Platz 1
71065 Sindelfingen
Deutschland
Tel +49 (0) 70 31 932-0
Fax +49 (0) 70 31 932-147
E-Mail: bitzer@bitzer.de
Internet: www.bitzer.de

* Symbols taken from english version of the Regulation 2015/1095

** Since condensing units are non functional systems Cdc can not be determined by test. For this reason the default degradation coefficient Cdc (0.25) has to be applied according to EN 13215, Annex A.



Performance Data Sheet according to EU Regulation 2015/1095

SEPR Declaration Model: LH124E/4CES-6Y

Refrigerant: R404A

Item	Symbol*	Value		Unit
Evaporating temperature	t	-10	-35	°C
Annual electricity consumption	Q	34775	24478	kWh/a
Seasonal Energy Performance Ratio	SEPR	3,19	1,83	

Point A: Parameters at full load and ambient temperature 32°C

Rated cooling capacity	P _A	18,04	6,02	kW
Rated power input	D _A	8,05	4,50	kW
Rated COP	COP_A	2,24	1,34	

Point B: Parameters at part load and ambient temperature 25°C

Declared cooling capacity	P _B	20,1	6,88	kW
Declared power input	D _B	7,57	4,41	kW
Declared COP	COP_B	2,65	1,56	

Point C: Parameters at part load and ambient temperature 15°C

Declared cooling capacity	P _C	23,0	8,13	kW
Declared power input	D _C	6,77	4,22	kW
Declared COP	COP_C	3,40	1,93	

Point D: Parameters at part load and ambient temperature 5°C

Declared cooling capacity	P _D	25,9	9,34	kW
Declared power input	D _D	5,86	3,94	kW
Declared COP	COP_D	4,42	2,37	

Point E: Parameters at full load and ambient temperature 43°C (information only)

Declared cooling capacity	P _E	14,84	4,75	kW
Declared power input	D _E	8,69	4,57	kW
Declared COP	COP_E	1,71	1,04	

Other items

Capacity control		—		
Reference temperature		Dew point temp.		
Suction gas temperature	to _h	20°C		
Power voltage	Net	400V/50Hz		
Coefficient of degradation for units w/o capacity control**	C _{dc}	0,25		

Additional document: [Declaration of Conformity AC-500](#)

Contact details:

BITZER Kühlmaschinenbau GmbH
Peter-Schaufler-Platz 1
71065 Sindelfingen
Deutschland
Tel +49 (0) 70 31 932-0
Fax +49 (0) 70 31 932-147
E-Mail: bitzer@bitzer.de
Internet: www.bitzer.de

* Symbols taken from english version of the Regulation 2015/1095

** Since condensing units are non functional systems C_{dc} can not be determined by test. For this reason the default degradation coefficient C_{dc} (0.25) has to be applied according to EN 13215, Annex A.



Performance Data Sheet according to EU Regulation 2015/1095

SEPR Declaration Model: LH124E/4CES-6Y

Refrigerant: R407A

Item	Symbol*	Value		Unit
Evaporating temperature	t	-10	-35	°C
Annual electricity consumption	Q	31526	20902	kWh/a
Seasonal Energy Performance Ratio	SEPR	3,15	1,62	

Point A: Parameters at full load and ambient temperature 32°C

Rated cooling capacity	P _A	16,17	4,55	kW
Rated power input	D _A	7,21	3,72	kW
Rated COP	COP_A	2,24	1,22	

Point B: Parameters at part load and ambient temperature 25°C

Declared cooling capacity	P _B	17,87	5,22	kW
Declared power input	D _B	6,78	3,68	kW
Declared COP	COP_B	2,64	1,42	

Point C: Parameters at part load and ambient temperature 15°C

Declared cooling capacity	P _C	20,3	6,16	kW
Declared power input	D _C	6,06	3,58	kW
Declared COP	COP_C	3,35	1,72	

Point D: Parameters at part load and ambient temperature 5°C

Declared cooling capacity	P _D	22,7	6,99	kW
Declared power input	D _D	5,23	3,41	kW
Declared COP	COP_D	4,34	2,05	

Point E: Parameters at full load and ambient temperature 43°C (information only)

Declared cooling capacity	P _E	13,55	3,57	kW
Declared power input	D _E	7,76	3,70	kW
Declared COP	COP_E	1,75	0,96	

Other items

Capacity control		—		
Reference temperature		Dew point temp.		
Suction gas temperature	to _h	20°C		
Power voltage	Net	400V/50Hz		
Coefficient of degradation for units w/o capacity control**	C _{dc}	0,25		

Additional document: [Declaration of Conformity AC-500](#)

Contact details:

BITZER Kühlmaschinenbau GmbH
Peter-Schaufler-Platz 1
71065 Sindelfingen
Deutschland
Tel +49 (0) 70 31 932-0
Fax +49 (0) 70 31 932-147
E-Mail: bitzer@bitzer.de
Internet: www.bitzer.de

* Symbols taken from english version of the Regulation 2015/1095

** Since condensing units are non functional systems C_{dc} can not be determined by test. For this reason the default degradation coefficient C_{dc} (0.25) has to be applied according to EN 13215, Annex A.



Performance Data Sheet according to EU Regulation 2015/1095

SEPR Declaration Model: LH124E/4CES-6Y

Refrigerant: R407C

Item	Symbol*	Value		Unit
Evaporating temperature	t	-10	-35	°C
Annual electricity consumption	Q	29939		kWh/a
Seasonal Energy Performance Ratio	SEPR	3,17		

Point A: Parameters at full load and ambient temperature 32°C

Rated cooling capacity	P _A	15,45		kW
Rated power input	D _A	6,75		kW
Rated COP	COP_A	2,29		

Point B: Parameters at part load and ambient temperature 25°C

Declared cooling capacity	P _B	17,01		kW
Declared power input	D _B	6,36		kW
Declared COP	COP_B	2,67		

Point C: Parameters at part load and ambient temperature 15°C

Declared cooling capacity	P _C	19,21		kW
Declared power input	D _C	5,70		kW
Declared COP	COP_C	3,37		

Point D: Parameters at part load and ambient temperature 5°C

Declared cooling capacity	P _D	21,4		kW
Declared power input	D _D	4,93		kW
Declared COP	COP_D	4,33		

Point E: Parameters at full load and ambient temperature 43°C (information only)

Declared cooling capacity	P _E	12,98		kW
Declared power input	D _E	7,21		kW
Declared COP	COP_E	1,80		

Other items

Capacity control		—		
Reference temperature		Dew point temp.		
Suction gas temperature	to _h	20°C		
Power voltage	Net	400V/50Hz		
Coefficient of degradation for units w/o capacity control**	C _{dc}	0,25		

Additional document: [Declaration of Conformity AC-500](#)

Contact details:

BITZER Kühlmaschinenbau GmbH
Peter-Schaufler-Platz 1
71065 Sindelfingen
Deutschland
Tel +49 (0) 70 31 932-0
Fax +49 (0) 70 31 932-147
E-Mail: bitzer@bitzer.de
Internet: www.bitzer.de

* Symbols taken from english version of the Regulation 2015/1095

** Since condensing units are non functional systems C_{dc} can not be determined by test. For this reason the default degradation coefficient C_{dc} (0.25) has to be applied according to EN 13215, Annex A.



Performance Data Sheet according to EU Regulation 2015/1095

SEPR Declaration Model: LH124E/4CES-6Y

Refrigerant: R407F

Item	Symbol*	Value		Unit
Evaporating temperature	t	-10	-35	°C
Annual electricity consumption	Q	33588	21919	kWh/a
Seasonal Energy Performance Ratio	SEPR	3,13	1,65	

Point A: Parameters at full load and ambient temperature 32°C

Rated cooling capacity	P _A	17,08	4,85	kW
Rated power input	D _A	7,66	3,91	kW
Rated COP	COP_A	2,23	1,24	

Point B: Parameters at part load and ambient temperature 25°C

Declared cooling capacity	P _B	18,78	5,53	kW
Declared power input	D _B	7,19	3,86	kW
Declared COP	COP_B	2,61	1,43	

Point C: Parameters at part load and ambient temperature 15°C

Declared cooling capacity	P _C	21,2	6,51	kW
Declared power input	D _C	6,41	3,74	kW
Declared COP	COP_C	3,31	1,74	

Point D: Parameters at part load and ambient temperature 5°C

Declared cooling capacity	P _D	23,7	7,40	kW
Declared power input	D _D	5,51	3,54	kW
Declared COP	COP_D	4,30	2,09	

Point E: Parameters at full load and ambient temperature 43°C (information only)

Declared cooling capacity	P _E	14,43	3,83	kW
Declared power input	D _E	8,26	3,90	kW
Declared COP	COP_E	1,75	0,98	

Other items

Capacity control	—			
Reference temperature	Dew point temp.			
Suction gas temperature	toh	20°C		
Power voltage	Net	400V/50Hz		
Coefficient of degradation for units w/o capacity control**	Cdc	0,25		

Additional document: [Declaration of Conformity AC-500](#)

Contact details:

BITZER Kühlmaschinenbau GmbH
Peter-Schaufler-Platz 1
71065 Sindelfingen
Deutschland
Tel +49 (0) 70 31 932-0
Fax +49 (0) 70 31 932-147
E-Mail: bitzer@bitzer.de
Internet: www.bitzer.de

* Symbols taken from english version of the Regulation 2015/1095

** Since condensing units are non functional systems Cdc can not be determined by test. For this reason the default degradation coefficient Cdc (0.25) has to be applied according to EN 13215, Annex A.



Performance Data Sheet according to EU Regulation 2015/1095

SEPR Declaration Model: LH124E/4CES-6Y

Refrigerant: R454C

Item	Symbol*	Value		Unit
Evaporating temperature	t	-10	-35	°C
Annual electricity consumption	Q	29464	20504	kWh/a
Seasonal Energy Performance Ratio	SEPR	3,08	1,58	

Point A: Parameters at full load and ambient temperature 32°C

Rated cooling capacity	P _A	14,78	4,34	kW
Rated power input	D _A	6,71	3,60	kW
Rated COP	COP_A	2,20	1,21	

Point B: Parameters at part load and ambient temperature 25°C

Declared cooling capacity	P _B	16,36	4,95	kW
Declared power input	D _B	6,32	3,57	kW
Declared COP	COP_B	2,59	1,39	

Point C: Parameters at part load and ambient temperature 15°C

Declared cooling capacity	P _C	18,62	5,83	kW
Declared power input	D _C	5,67	3,48	kW
Declared COP	COP_C	3,28	1,67	

Point D: Parameters at part load and ambient temperature 5°C

Declared cooling capacity	P _D	20,8	6,59	kW
Declared power input	D _D	4,92	3,33	kW
Declared COP	COP_D	4,24	1,98	

Point E: Parameters at full load and ambient temperature 43°C (information only)

Declared cooling capacity	P _E	12,34	3,41	kW
Declared power input	D _E	7,21	3,58	kW
Declared COP	COP_E	1,71	0,95	

Other items

Capacity control		—		
Reference temperature		Dew point temp.		
Suction gas temperature	to _h	20°C		
Power voltage	Net	400V/50Hz		
Coefficient of degradation for units w/o capacity control**	C _{dc}	0,25		

Additional document: [Declaration of Conformity AC-500](#)

Contact details:

BITZER Kühlmaschinenbau GmbH
Peter-Schaufler-Platz 1
71065 Sindelfingen
Deutschland
Tel +49 (0) 70 31 932-0
Fax +49 (0) 70 31 932-147
E-Mail: bitzer@bitzer.de
Internet: www.bitzer.de

* Symbols taken from english version of the Regulation 2015/1095

** Since condensing units are non functional systems C_{dc} can not be determined by test. For this reason the default degradation coefficient C_{dc} (0.25) has to be applied according to EN 13215, Annex A.



Performance Data Sheet according to EU Regulation 2015/1095

SEPR Declaration Model: LH124E/4CES-6Y

Refrigerant: R455A

Item	Symbol*	Value		Unit
Evaporating temperature	t	-10	-35	°C
Annual electricity consumption	Q	32826	21194	kWh/a
Seasonal Energy Performance Ratio	SEPR	2,71	1,47	

Point A: Parameters at full load and ambient temperature 32°C

Rated cooling capacity	P _A	14,49	4,17	kW
Rated power input	D _A	7,39	3,78	kW
Rated COP	COP_A	1,96	1,10	

Point B: Parameters at part load and ambient temperature 25°C

Declared cooling capacity	P _B	16,15	4,82	kW
Declared power input	D _B	7,02	3,78	kW
Declared COP	COP_B	2,30	1,27	

Point C: Parameters at part load and ambient temperature 15°C

Declared cooling capacity	P _C	18,55	5,77	kW
Declared power input	D _C	6,39	3,71	kW
Declared COP	COP_C	2,90	1,56	

Point D: Parameters at part load and ambient temperature 5°C

Declared cooling capacity	P _D	20,9	6,70	kW
Declared power input	D _D	5,65	3,57	kW
Declared COP	COP_D	3,71	1,87	

Point E: Parameters at full load and ambient temperature 43°C (information only)

Declared cooling capacity	P _E	--	--	kW
Declared power input	D _E	--	--	kW
Declared COP	COP_E	--	--	

Other items

Capacity control		—		
Reference temperature		Dew point temp.		
Suction gas temperature	toh	20°C		
Power voltage	Net	400V/50Hz		
Coefficient of degradation for units w/o capacity control**	Cdc	0,25		

Additional document: [Declaration of Conformity AC-500](#)

Contact details:

BITZER Kühlmaschinenbau GmbH
Peter-Schaufler-Platz 1
71065 Sindelfingen
Deutschland
Tel +49 (0) 70 31 932-0
Fax +49 (0) 70 31 932-147
E-Mail: bitzer@bitzer.de
Internet: www.bitzer.de

* Symbols taken from english version of the Regulation 2015/1095

** Since condensing units are non functional systems Cdc can not be determined by test. For this reason the default degradation coefficient Cdc (0.25) has to be applied according to EN 13215, Annex A.



Performance Data Sheet according to EU Regulation 2015/1095

SEPR Declaration Model: LH124E/4CES-6Y

Refrigerant: R507A

Item	Symbol*	Value		Unit
Evaporating temperature	t	-10	-35	°C
Annual electricity consumption	Q	34852	24489	kWh/a
Seasonal Energy Performance Ratio	SEPR	3,26	1,92	

Point A: Parameters at full load and ambient temperature 32°C

Rated cooling capacity	P _A	18,49	6,30	kW
Rated power input	D _A	8,07	4,51	kW
Rated COP	COP_A	2,29	1,40	

Point B: Parameters at part load and ambient temperature 25°C

Declared cooling capacity	P _B	20,6	7,20	kW
Declared power input	D _B	7,59	4,42	kW
Declared COP	COP_B	2,72	1,63	

Point C: Parameters at part load and ambient temperature 15°C

Declared cooling capacity	P _C	23,6	8,51	kW
Declared power input	D _C	6,80	4,22	kW
Declared COP	COP_C	3,48	2,02	

Point D: Parameters at part load and ambient temperature 5°C

Declared cooling capacity	P _D	26,7	9,79	kW
Declared power input	D _D	5,90	3,95	kW
Declared COP	COP_D	4,52	2,48	

Point E: Parameters at full load and ambient temperature 43°C (information only)

Declared cooling capacity	P _E	15,16	4,97	kW
Declared power input	D _E	8,70	4,57	kW
Declared COP	COP_E	1,74	1,09	

Other items

Capacity control		—		
Reference temperature		Dew point temp.		
Suction gas temperature	to _h	20°C		
Power voltage	Net	400V/50Hz		
Coefficient of degradation for units w/o capacity control**	C _{dc}	0,25		

Additional document: [Declaration of Conformity AC-500](#)

Contact details:

BITZER Kühlmaschinenbau GmbH
Peter-Schaufler-Platz 1
71065 Sindelfingen
Deutschland
Tel +49 (0) 70 31 932-0
Fax +49 (0) 70 31 932-147
E-Mail: bitzer@bitzer.de
Internet: www.bitzer.de

* Symbols taken from english version of the Regulation 2015/1095

** Since condensing units are non functional systems C_{dc} can not be determined by test. For this reason the default degradation coefficient C_{dc} (0.25) has to be applied according to EN 13215, Annex A.



Performance Data Sheet according to EU Regulation 2015/1095

SEPR Declaration Model: LH124E/4CES-6Y

Refrigerant: R448A

Item	Symbol*	Value		Unit
Evaporating temperature	t	-10	-35	°C
Annual electricity consumption	Q	32561	22005	kWh/a
Seasonal Energy Performance Ratio	SEPR	3,15	1,66	

Point A: Parameters at full load and ambient temperature 32°C

Rated cooling capacity	P _A	16,70	4,89	kW
Rated power input	D _A	7,46	3,92	kW
Rated COP	COP_A	2,24	1,25	

Point B: Parameters at part load and ambient temperature 25°C

Declared cooling capacity	P _B	18,42	5,58	kW
Declared power input	D _B	7,00	3,88	kW
Declared COP	COP_B	2,63	1,44	

Point C: Parameters at part load and ambient temperature 15°C

Declared cooling capacity	P _C	20,9	6,56	kW
Declared power input	D _C	6,24	3,75	kW
Declared COP	COP_C	3,35	1,75	

Point D: Parameters at part load and ambient temperature 5°C

Declared cooling capacity	P _D	23,3	7,46	kW
Declared power input	D _D	5,37	3,56	kW
Declared COP	COP_D	4,34	2,10	

Point E: Parameters at full load and ambient temperature 43°C (information only)

Declared cooling capacity	P _E	14,03	3,87	kW
Declared power input	D _E	8,05	3,91	kW
Declared COP	COP_E	1,74	0,99	

Other items

Capacity control		—		
Reference temperature		Dew point temp.		
Suction gas temperature	to _h	20°C		
Power voltage	Net	400V/50Hz		
Coefficient of degradation for units w/o capacity control**	C _{dc}	0,25		

Additional document: [Declaration of Conformity AC-500](#)

Contact details:

BITZER Kühlmaschinenbau GmbH
Peter-Schaufler-Platz 1
71065 Sindelfingen
Deutschland
Tel +49 (0) 70 31 932-0
Fax +49 (0) 70 31 932-147
E-Mail: bitzer@bitzer.de
Internet: www.bitzer.de

* Symbols taken from english version of the Regulation 2015/1095

** Since condensing units are non functional systems C_{dc} can not be determined by test. For this reason the default degradation coefficient C_{dc} (0.25) has to be applied according to EN 13215, Annex A.



Performance Data Sheet according to EU Regulation 2015/1095

SEPR Declaration Model: LH124E/4CES-6Y

Refrigerant: R449A

Item	Symbol*	Value		Unit
Evaporating temperature	t	-10	-35	°C
Annual electricity consumption	Q	32511	21986	kWh/a
Seasonal Energy Performance Ratio	SEPR	3,14	1,66	

Point A: Parameters at full load and ambient temperature 32°C

Rated cooling capacity	P _A	16,62	4,89	kW
Rated power input	D _A	7,45	3,92	kW
Rated COP	COP_A	2,23	1,25	

Point B: Parameters at part load and ambient temperature 25°C

Declared cooling capacity	P _B	18,34	5,57	kW
Declared power input	D _B	7,00	3,88	kW
Declared COP	COP_B	2,62	1,44	

Point C: Parameters at part load and ambient temperature 15°C

Declared cooling capacity	P _C	20,8	6,56	kW
Declared power input	D _C	6,24	3,75	kW
Declared COP	COP_C	3,34	1,75	

Point D: Parameters at part load and ambient temperature 5°C

Declared cooling capacity	P _D	23,3	7,47	kW
Declared power input	D _D	5,37	3,56	kW
Declared COP	COP_D	4,33	2,10	

Point E: Parameters at full load and ambient temperature 43°C (information only)

Declared cooling capacity	P _E	13,95	3,86	kW
Declared power input	D _E	8,05	3,91	kW
Declared COP	COP_E	1,73	0,99	

Other items

Capacity control	—		
Reference temperature	Dew point temp.		
Suction gas temperature	toh	20°C	
Power voltage	Net	400V/50Hz	
Coefficient of degradation for units w/o capacity control**	Cdc	0,25	

Additional document: [Declaration of Conformity AC-500](#)

Contact details:

BITZER Kühlmaschinenbau GmbH
Peter-Schaufler-Platz 1
71065 Sindelfingen
Deutschland
Tel +49 (0) 70 31 932-0
Fax +49 (0) 70 31 932-147
E-Mail: bitzer@bitzer.de
Internet: www.bitzer.de

* Symbols taken from english version of the Regulation 2015/1095

** Since condensing units are non functional systems Cdc can not be determined by test. For this reason the default degradation coefficient Cdc (0.25) has to be applied according to EN 13215, Annex A.



Performance Data Sheet according to EU Regulation 2015/1095

SEPR Declaration Model: LH124E/4CES-6Y

Refrigerant: R450A

Item	Symbol*	Value		Unit
Evaporating temperature	t	-10	-35	°C
Annual electricity consumption	Q	18070		kWh/a
Seasonal Energy Performance Ratio	SEPR	3,28		

Point A: Parameters at full load and ambient temperature 32°C

Rated cooling capacity	P _A	9,65		kW
Rated power input	D _A	4,00		kW
Rated COP	COP_A	2,41		

Point B: Parameters at part load and ambient temperature 25°C

Declared cooling capacity	P _B	10,53		kW
Declared power input	D _B	3,75		kW
Declared COP	COP_B	2,81		

Point C: Parameters at part load and ambient temperature 15°C

Declared cooling capacity	P _C	11,78		kW
Declared power input	D _C	3,34		kW
Declared COP	COP_C	3,53		

Point D: Parameters at part load and ambient temperature 5°C

Declared cooling capacity	P _D	12,81		kW
Declared power input	D _D	2,95		kW
Declared COP	COP_D	4,34		

Point E: Parameters at full load and ambient temperature 43°C (information only)

Declared cooling capacity	P _E	8,23		kW
Declared power input	D _E	4,33		kW
Declared COP	COP_E	1,90		

Other items

Capacity control		—		
Reference temperature		Dew point temp.		
Suction gas temperature	toh	20°C		
Power voltage	Net	400V/50Hz		
Coefficient of degradation for units w/o capacity control**	Cdc	0,25		

Additional document: [Declaration of Conformity AC-500](#)

Contact details:

BITZER Kühlmaschinenbau GmbH
 Peter-Schaufler-Platz 1
 71065 Sindelfingen
 Deutschland
 Tel +49 (0) 70 31 932-0
 Fax +49 (0) 70 31 932-147
 E-Mail: bitzer@bitzer.de
 Internet: www.bitzer.de

* Symbols taken from english version of the Regulation 2015/1095

** Since condensing units are non functional systems Cdc can not be determined by test. For this reason the default degradation coefficient Cdc (0.25) has to be applied according to EN 13215, Annex A.



Performance Data Sheet according to EU Regulation 2015/1095

SEPR Declaration Model: LH124E/4CES-6Y

Refrigerant: R513A

Item	Symbol*	Value		Unit
Evaporating temperature	t	-10	-35	°C
Annual electricity consumption	Q	20769		kWh/a
Seasonal Energy Performance Ratio	SEPR	3,45		

Point A: Parameters at full load and ambient temperature 32°C

Rated cooling capacity	P _A	11,65		kW
Rated power input	D _A	4,69		kW
Rated COP	COP_A	2,49		

Point B: Parameters at part load and ambient temperature 25°C

Declared cooling capacity	P _B	12,77		kW
Declared power input	D _B	4,39		kW
Declared COP	COP_B	2,91		

Point C: Parameters at part load and ambient temperature 15°C

Declared cooling capacity	P _C	14,32		kW
Declared power input	D _C	3,91		kW
Declared COP	COP_C	3,67		

Point D: Parameters at part load and ambient temperature 5°C

Declared cooling capacity	P _D	15,80		kW
Declared power input	D _D	3,37		kW
Declared COP	COP_D	4,68		

Point E: Parameters at full load and ambient temperature 43°C (information only)

Declared cooling capacity	P _E	9,87		kW
Declared power input	D _E	5,06		kW
Declared COP	COP_E	1,95		

Other items

Capacity control		—		
Reference temperature		Dew point temp.		
Suction gas temperature	toh	20°C		
Power voltage	Net	400V/50Hz		
Coefficient of degradation for units w/o capacity control**	Cdc	0,25		

Additional document: [Declaration of Conformity AC-500](#)

Contact details:

BITZER Kühlmaschinenbau GmbH
Peter-Schaufler-Platz 1
71065 Sindelfingen
Deutschland
Tel +49 (0) 70 31 932-0
Fax +49 (0) 70 31 932-147
E-Mail: bitzer@bitzer.de
Internet: www.bitzer.de

* Symbols taken from english version of the Regulation 2015/1095

** Since condensing units are non functional systems Cdc can not be determined by test. For this reason the default degradation coefficient Cdc (0.25) has to be applied according to EN 13215, Annex A.



Performance Data Sheet according to EU Regulation 2015/1095

SEPR Declaration Model: LH124E/4CES-6Y

Refrigerant: R1234yf

Item	Symbol*	Value		Unit
Evaporating temperature	t	-10	-35	°C
Annual electricity consumption	Q	20147		kWh/a
Seasonal Energy Performance Ratio	SEPR	3,42		

Point A: Parameters at full load and ambient temperature 32°C

Rated cooling capacity	P _A	11,22		kW
Rated power input	D _A	4,59		kW
Rated COP	COP_A	2,45		

Point B: Parameters at part load and ambient temperature 25°C

Declared cooling capacity	P _B	12,34		kW
Declared power input	D _B	4,29		kW
Declared COP	COP_B	2,87		

Point C: Parameters at part load and ambient temperature 15°C

Declared cooling capacity	P _C	13,91		kW
Declared power input	D _C	3,81		kW
Declared COP	COP_C	3,65		

Point D: Parameters at part load and ambient temperature 5°C

Declared cooling capacity	P _D	15,39		kW
Declared power input	D _D	3,30		kW
Declared COP	COP_D	4,67		

Point E: Parameters at full load and ambient temperature 43°C (information only)

Declared cooling capacity	P _E	9,46		kW
Declared power input	D _E	4,98		kW
Declared COP	COP_E	1,90		

Other items

Capacity control		—		
Reference temperature		Dew point temp.		
Suction gas temperature	toh	20°C		
Power voltage	Net	400V/50Hz		
Coefficient of degradation for units w/o capacity control**	Cdc	0,25		

Additional document: [Declaration of Conformity AC-500](#)

Contact details:

BITZER Kühlmaschinenbau GmbH
Peter-Schaufler-Platz 1
71065 Sindelfingen
Deutschland
Tel +49 (0) 70 31 932-0
Fax +49 (0) 70 31 932-147
E-Mail: bitzer@bitzer.de
Internet: www.bitzer.de

* Symbols taken from english version of the Regulation 2015/1095

** Since condensing units are non functional systems Cdc can not be determined by test. For this reason the default degradation coefficient Cdc (0.25) has to be applied according to EN 13215, Annex A.



Performance Data Sheet according to EU Regulation 2015/1095

SEPR Declaration Model: LH124E/4CES-6Y

Refrigerant: R1234ze

Item	Symbol*	Value		Unit
Evaporating temperature	t	-10	-35	°C
Annual electricity consumption	Q	16427		kWh/a
Seasonal Energy Performance Ratio	SEPR	3,12		

Point A: Parameters at full load and ambient temperature 32°C

Rated cooling capacity	P _A	8,34		kW
Rated power input	D _A	3,50		kW
Rated COP	COP_A	2,38		

Point B: Parameters at part load and ambient temperature 25°C

Declared cooling capacity	P _B	9,07		kW
Declared power input	D _B	3,28		kW
Declared COP	COP_B	2,76		

Point C: Parameters at part load and ambient temperature 15°C

Declared cooling capacity	P _C	10,10		kW
Declared power input	D _C	2,93		kW
Declared COP	COP_C	3,45		

Point D: Parameters at part load and ambient temperature 5°C

Declared cooling capacity	P _D	10,68		kW
Declared power input	D _D	2,72		kW
Declared COP	COP_D	3,93		

Point E: Parameters at full load and ambient temperature 43°C (information only)

Declared cooling capacity	P _E	7,18		kW
Declared power input	D _E	3,79		kW
Declared COP	COP_E	1,89		

Other items

Capacity control		—		
Reference temperature		Dew point temp.		
Suction gas temperature	toh	20°C		
Power voltage	Net	400V/50Hz		
Coefficient of degradation for units w/o capacity control**	Cdc	0,25		

Additional document: [Declaration of Conformity AC-500](#)

Contact details:

BITZER Kühlmaschinenbau GmbH
Peter-Schaufler-Platz 1
71065 Sindelfingen
Deutschland
Tel +49 (0) 70 31 932-0
Fax +49 (0) 70 31 932-147
E-Mail: bitzer@bitzer.de
Internet: www.bitzer.de

* Symbols taken from english version of the Regulation 2015/1095

** Since condensing units are non functional systems Cdc can not be determined by test. For this reason the default degradation coefficient Cdc (0.25) has to be applied according to EN 13215, Annex A.