



## Performance Data Sheet according to EU Regulation 2015/1095

### SEPR Declaration Model: LH84E/4EES-6Y

#### Refrigerant: R134a

Item	Symbol*	Value	Unit
Evaporating temperature	t	-10	°C
Annual electricity consumption	Q	13611	kWh/a
Seasonal Energy Performance Ratio	SEPR	3,37	

#### Point A: Parameters at full load and ambient temperature 32°C

Rated cooling capacity	P <sub>A</sub>	7,47		kW
Rated power input	D <sub>A</sub>	3,05		kW
<b>Rated COP</b>	<b>COP<sub>A</sub></b>	<b>2,45</b>		

#### Point B: Parameters at part load and ambient temperature 25°C

Declared cooling capacity	P <sub>B</sub>	8,17		kW
Declared power input	D <sub>B</sub>	2,87		kW
<b>Declared COP</b>	<b>COP<sub>B</sub></b>	<b>2,85</b>		

#### Point C: Parameters at part load and ambient temperature 15°C

Declared cooling capacity	P <sub>C</sub>	9,18		kW
Declared power input	D <sub>C</sub>	2,56		kW
<b>Declared COP</b>	<b>COP<sub>C</sub></b>	<b>3,58</b>		

#### Point D: Parameters at part load and ambient temperature 5°C

Declared cooling capacity	P <sub>D</sub>	10,17		kW
Declared power input	D <sub>D</sub>	2,22		kW
<b>Declared COP</b>	<b>COP<sub>D</sub></b>	<b>4,59</b>		

#### Point E: Parameters at full load and ambient temperature 43°C (information only)

Declared cooling capacity	P <sub>E</sub>	6,37		kW
Declared power input	D <sub>E</sub>	3,28		kW
<b>Declared COP</b>	<b>COP<sub>E</sub></b>	<b>1,94</b>		

#### Other items

Capacity control	—		
Reference temperature	Dew point temp.		
Suction gas temperature	toh	20°C	
Power voltage	Net	400V/50Hz	
Coefficient of degradation for units w/o capacity control**	Cdc	0,25	

Additional document: [Declaration of Conformity AC-500](#)

#### Contact details:

BITZER Kühlmaschinenbau GmbH  
Peter-Schaufler-Platz 1  
71065 Sindelfingen  
Deutschland  
Tel +49 (0) 70 31 932-0  
Fax +49 (0) 70 31 932-147  
E-Mail: [bitzer@bitzer.de](mailto:bitzer@bitzer.de)  
Internet: [www.bitzer.de](http://www.bitzer.de)

\* Symbols taken from english version of the Regulation 2015/1095

\*\* Since condensing units are non functional systems Cdc can not be determined by test. For this reason the default degradation coefficient Cdc (0.25) has to be applied according to EN 13215, Annex A.



## Performance Data Sheet according to EU Regulation 2015/1095

### SEPR Declaration Model: LH84E/4EES-6Y

#### Refrigerant: R404A

Item	Symbol*	Value		Unit
Evaporating temperature	t	-10	-35	°C
Annual electricity consumption	Q	24144	16593	kWh/a
Seasonal Energy Performance Ratio	SEPR	2,97	1,81	

#### Point A: Parameters at full load and ambient temperature 32°C

Rated cooling capacity	P <sub>A</sub>	11,65	4,02	kW
Rated power input	D <sub>A</sub>	5,53	3,03	kW
Rated COP	COP <sub>A</sub>	2,11	1,33	

#### Point B: Parameters at part load and ambient temperature 25°C

Declared cooling capacity	P <sub>B</sub>	13,06	4,56	kW
Declared power input	D <sub>B</sub>	5,24	2,97	kW
Declared COP	COP <sub>B</sub>	2,49	1,54	

#### Point C: Parameters at part load and ambient temperature 15°C

Declared cooling capacity	P <sub>C</sub>	15,03	5,30	kW
Declared power input	D <sub>C</sub>	4,74	2,81	kW
Declared COP	COP <sub>C</sub>	3,17	1,89	

#### Point D: Parameters at part load and ambient temperature 5°C

Declared cooling capacity	P <sub>D</sub>	16,92	6,00	kW
Declared power input	D <sub>D</sub>	4,14	2,58	kW
Declared COP	COP <sub>D</sub>	4,09	2,33	

#### Point E: Parameters at full load and ambient temperature 43°C (information only)

Declared cooling capacity	P <sub>E</sub>	9,39	3,16	kW
Declared power input	D <sub>E</sub>	5,87	3,04	kW
Declared COP	COP <sub>E</sub>	1,60	1,04	

#### Other items

Capacity control	—		
Reference temperature	Dew point temp.		
Suction gas temperature	toh	20°C	
Power voltage	Net	400V/50Hz	
Coefficient of degradation for units w/o capacity control**	Cdc	0,25	

Additional document: [Declaration of Conformity AC-500](#)

#### Contact details:

BITZER Kühlmaschinenbau GmbH  
Peter-Schaufel-Platz 1  
71065 Sindelfingen  
Deutschland  
Tel +49 (0) 70 31 932-0  
Fax +49 (0) 70 31 932-147  
E-Mail: [bitzer@bitzer.de](mailto:bitzer@bitzer.de)  
Internet: [www.bitzer.de](http://www.bitzer.de)

\* Symbols taken from english version of the Regulation 2015/1095

\*\* Since condensing units are non functional systems Cdc can not be determined by test. For this reason the default degradation coefficient Cdc (0.25) has to be applied according to EN 13215, Annex A.



## Performance Data Sheet according to EU Regulation 2015/1095

### SEPR Declaration Model: LH84E/4EES-6Y

#### Refrigerant: R407A

Item	Symbol*	Value	Unit
Evaporating temperature	t	-10	°C
Annual electricity consumption	Q	22006	kWh/a
Seasonal Energy Performance Ratio	SEPR	2,96	1,62

#### Point A: Parameters at full load and ambient temperature 32°C

Rated cooling capacity	P <sub>A</sub>	10,60	2,97	kW
Rated power input	D <sub>A</sub>	4,94	2,38	kW
Rated COP	COP <sub>A</sub>	2,14	1,24	

#### Point B: Parameters at part load and ambient temperature 25°C

Declared cooling capacity	P <sub>B</sub>	11,76	3,44	kW
Declared power input	D <sub>B</sub>	4,68	2,37	kW
Declared COP	COP <sub>B</sub>	2,51	1,45	

#### Point C: Parameters at part load and ambient temperature 15°C

Declared cooling capacity	P <sub>C</sub>	13,43	4,11	kW
Declared power input	D <sub>C</sub>	4,23	2,34	kW
Declared COP	COP <sub>C</sub>	3,17	1,75	

#### Point D: Parameters at part load and ambient temperature 5°C

Declared cooling capacity	P <sub>D</sub>	15,08	4,72	kW
Declared power input	D <sub>D</sub>	3,75	2,34	kW
Declared COP	COP <sub>D</sub>	4,02	2,01	

#### Point E: Parameters at full load and ambient temperature 43°C (information only)

Declared cooling capacity	P <sub>E</sub>	8,80	2,27	kW
Declared power input	D <sub>E</sub>	5,25	2,35	kW
Declared COP	COP <sub>E</sub>	1,68	0,97	

#### Other items

Capacity control	—		
Reference temperature	Dew point temp.		
Suction gas temperature	toh	20°C	
Power voltage	Net	400V/50Hz	
Coefficient of degradation for units w/o capacity control**	Cdc	0,25	

Additional document: [Declaration of Conformity AC-500](#)

#### Contact details:

BITZER Kühlmaschinenbau GmbH  
Peter-Schaufel-Platz 1  
71065 Sindelfingen  
Deutschland  
Tel +49 (0) 70 31 932-0  
Fax +49 (0) 70 31 932-147  
E-Mail: [bitzer@bitzer.de](mailto:bitzer@bitzer.de)  
Internet: [www.bitzer.de](http://www.bitzer.de)

\* Symbols taken from english version of the Regulation 2015/1095

\*\* Since condensing units are non functional systems Cdc can not be determined by test. For this reason the default degradation coefficient Cdc (0.25) has to be applied according to EN 13215, Annex A.



## Performance Data Sheet according to EU Regulation 2015/1095

### SEPR Declaration Model: LH84E/4EES-6Y

#### Refrigerant: R407C

Item	Symbol*	Value	Unit
Evaporating temperature	t	-10	°C
Annual electricity consumption	Q	20430	kWh/a
Seasonal Energy Performance Ratio	SEPR	3,00	

#### Point A: Parameters at full load and ambient temperature 32°C

Rated cooling capacity	P <sub>A</sub>	9,96		kW
Rated power input	D <sub>A</sub>	4,50		kW
<b>Rated COP</b>	<b>COP<sub>A</sub></b>	<b>2,21</b>		

#### Point B: Parameters at part load and ambient temperature 25°C

Declared cooling capacity	P <sub>B</sub>	11,06		kW
Declared power input	D <sub>B</sub>	4,30		kW
<b>Declared COP</b>	<b>COP<sub>B</sub></b>	<b>2,57</b>		

#### Point C: Parameters at part load and ambient temperature 15°C

Declared cooling capacity	P <sub>C</sub>	12,60		kW
Declared power input	D <sub>C</sub>	3,93		kW
<b>Declared COP</b>	<b>COP<sub>C</sub></b>	<b>3,20</b>		

#### Point D: Parameters at part load and ambient temperature 5°C

Declared cooling capacity	P <sub>D</sub>	14,12		kW
Declared power input	D <sub>D</sub>	3,48		kW
<b>Declared COP</b>	<b>COP<sub>D</sub></b>	<b>4,06</b>		

#### Point E: Parameters at full load and ambient temperature 43°C (information only)

Declared cooling capacity	P <sub>E</sub>	8,24		kW
Declared power input	D <sub>E</sub>	4,70		kW
<b>Declared COP</b>	<b>COP<sub>E</sub></b>	<b>1,75</b>		

#### Other items

Capacity control	—		
Reference temperature	Dew point temp.		
Suction gas temperature	toh	20°C	
Power voltage	Net	400V/50Hz	
Coefficient of degradation for units w/o capacity control**	Cdc	0,25	

Additional document: [Declaration of Conformity AC-500](#)

#### Contact details:

BITZER Kühlmaschinenbau GmbH  
Peter-Schaufler-Platz 1  
71065 Sindelfingen  
Deutschland  
Tel +49 (0) 70 31 932-0  
Fax +49 (0) 70 31 932-147  
E-Mail: [bitzer@bitzer.de](mailto:bitzer@bitzer.de)  
Internet: [www.bitzer.de](http://www.bitzer.de)

\* Symbols taken from english version of the Regulation 2015/1095

\*\* Since condensing units are non functional systems Cdc can not be determined by test. For this reason the default degradation coefficient Cdc (0.25) has to be applied according to EN 13215, Annex A.



## Performance Data Sheet according to EU Regulation 2015/1095

### SEPR Declaration Model: LH84E/4EES-6Y

#### Refrigerant: R407F

Item	Symbol*	Value		Unit
Evaporating temperature	t	-10	-35	°C
Annual electricity consumption	Q	23524	14343	kWh/a
Seasonal Energy Performance Ratio	SEPR	2,92	1,64	

#### Point A: Parameters at full load and ambient temperature 32°C

Rated cooling capacity	P <sub>A</sub>	11,19	3,16	kW
Rated power input	D <sub>A</sub>	5,27	2,51	kW
Rated COP	COP <sub>A</sub>	2,12	1,26	

#### Point B: Parameters at part load and ambient temperature 25°C

Declared cooling capacity	P <sub>B</sub>	12,36	3,65	kW
Declared power input	D <sub>B</sub>	4,98	2,50	kW
Declared COP	COP <sub>B</sub>	2,48	1,46	

#### Point C: Parameters at part load and ambient temperature 15°C

Declared cooling capacity	P <sub>C</sub>	14,05	4,35	kW
Declared power input	D <sub>C</sub>	4,49	2,45	kW
Declared COP	COP <sub>C</sub>	3,13	1,77	

#### Point D: Parameters at part load and ambient temperature 5°C

Declared cooling capacity	P <sub>D</sub>	15,72	4,99	kW
Declared power input	D <sub>D</sub>	3,97	2,44	kW
Declared COP	COP <sub>D</sub>	3,96	2,05	

#### Point E: Parameters at full load and ambient temperature 43°C (information only)

Declared cooling capacity	P <sub>E</sub>	9,36	2,44	kW
Declared power input	D <sub>E</sub>	5,60	2,48	kW
Declared COP	COP <sub>E</sub>	1,67	0,98	

#### Other items

Capacity control	—		
Reference temperature	Dew point temp.		
Suction gas temperature	toh	20°C	
Power voltage	Net	400V/50Hz	
Coefficient of degradation for units w/o capacity control**	Cdc	0,25	

Additional document: [Declaration of Conformity AC-500](#)

#### Contact details:

BITZER Kühlmaschinenbau GmbH  
Peter-Schaufler-Platz 1  
71065 Sindelfingen  
Deutschland  
Tel +49 (0) 70 31 932-0  
Fax +49 (0) 70 31 932-147  
E-Mail: [bitzer@bitzer.de](mailto:bitzer@bitzer.de)  
Internet: [www.bitzer.de](http://www.bitzer.de)

\* Symbols taken from english version of the Regulation 2015/1095

\*\* Since condensing units are non functional systems Cdc can not be determined by test. For this reason the default degradation coefficient Cdc (0.25) has to be applied according to EN 13215, Annex A.



## Performance Data Sheet according to EU Regulation 2015/1095

### SEPR Declaration Model: LH84E/4EES-6Y

#### Refrigerant: R454C

Item	Symbol*	Value	Unit
Evaporating temperature	t	-10	°C
Annual electricity consumption	Q	20501	kWh/a
Seasonal Energy Performance Ratio	SEPR	2,92	1,57

#### Point A: Parameters at full load and ambient temperature 32°C

Rated cooling capacity	P <sub>A</sub>	9,72	2,84	kW
Rated power input	D <sub>A</sub>	4,58	2,30	kW
Rated COP	COP <sub>A</sub>	2,12	1,23	

#### Point B: Parameters at part load and ambient temperature 25°C

Declared cooling capacity	P <sub>B</sub>	10,80	3,28	kW
Declared power input	D <sub>B</sub>	4,33	2,30	kW
Declared COP	COP <sub>B</sub>	2,49	1,43	

#### Point C: Parameters at part load and ambient temperature 15°C

Declared cooling capacity	P <sub>C</sub>	12,35	3,90	kW
Declared power input	D <sub>C</sub>	3,94	2,29	kW
Declared COP	COP <sub>C</sub>	3,14	1,70	

#### Point D: Parameters at part load and ambient temperature 5°C

Declared cooling capacity	P <sub>D</sub>	13,87	4,45	kW
Declared power input	D <sub>D</sub>	3,53	2,32	kW
Declared COP	COP <sub>D</sub>	3,93	1,92	

#### Point E: Parameters at full load and ambient temperature 43°C (information only)

Declared cooling capacity	P <sub>E</sub>	8,05	2,19	kW
Declared power input	D <sub>E</sub>	4,88	2,26	kW
Declared COP	COP <sub>E</sub>	1,65	0,97	

#### Other items

Capacity control	—		
Reference temperature	Dew point temp.		
Suction gas temperature	toh	20°C	
Power voltage	Net	400V/50Hz	
Coefficient of degradation for units w/o capacity control**	Cdc	0,25	

Additional document: [Declaration of Conformity AC-500](#)

#### Contact details:

BITZER Kühlmaschinenbau GmbH  
Peter-Schaufler-Platz 1  
71065 Sindelfingen  
Deutschland  
Tel +49 (0) 70 31 932-0  
Fax +49 (0) 70 31 932-147  
E-Mail: [bitzer@bitzer.de](mailto:bitzer@bitzer.de)  
Internet: [www.bitzer.de](http://www.bitzer.de)

\* Symbols taken from english version of the Regulation 2015/1095

\*\* Since condensing units are non functional systems Cdc can not be determined by test. For this reason the default degradation coefficient Cdc (0.25) has to be applied according to EN 13215, Annex A.



## Performance Data Sheet according to EU Regulation 2015/1095

### SEPR Declaration Model: LH84E/4EES-6Y

#### Refrigerant: R455A

Item	Symbol*	Value		Unit
Evaporating temperature	t	-10	-35	°C
Annual electricity consumption	Q	22587	13570	kWh/a
Seasonal Energy Performance Ratio	SEPR	2,58	1,48	

#### Point A: Parameters at full load and ambient temperature 32°C

Rated cooling capacity	P <sub>A</sub>	9,47	2,70	kW
Rated power input	D <sub>A</sub>	5,04	2,42	kW
Rated COP	COP <sub>A</sub>	1,88	1,12	

#### Point B: Parameters at part load and ambient temperature 25°C

Declared cooling capacity	P <sub>B</sub>	10,60	3,16	kW
Declared power input	D <sub>B</sub>	4,81	2,43	kW
Declared COP	COP <sub>B</sub>	2,20	1,30	

#### Point C: Parameters at part load and ambient temperature 15°C

Declared cooling capacity	P <sub>C</sub>	12,24	3,83	kW
Declared power input	D <sub>C</sub>	4,42	2,40	kW
Declared COP	COP <sub>C</sub>	2,77	1,59	

#### Point D: Parameters at part load and ambient temperature 5°C

Declared cooling capacity	P <sub>D</sub>	13,88	4,49	kW
Declared power input	D <sub>D</sub>	3,97	2,38	kW
Declared COP	COP <sub>D</sub>	3,50	1,88	

#### Point E: Parameters at full load and ambient temperature 43°C (information only)

Declared cooling capacity	P <sub>E</sub>	--	--	kW
Declared power input	D <sub>E</sub>	--	--	kW
Declared COP	COP <sub>E</sub>	--	--	

#### Other items

Capacity control	—		
Reference temperature	Dew point temp.		
Suction gas temperature	toh	20°C	
Power voltage	Net	400V/50Hz	
Coefficient of degradation for units w/o capacity control**	Cdc	0,25	

Additional document: [Declaration of Conformity AC-500](#)

#### Contact details:

BITZER Kühlmaschinenbau GmbH  
Peter-Schaufler-Platz 1  
71065 Sindelfingen  
Deutschland  
Tel +49 (0) 70 31 932-0  
Fax +49 (0) 70 31 932-147  
E-Mail: [bitzer@bitzer.de](mailto:bitzer@bitzer.de)  
Internet: [www.bitzer.de](http://www.bitzer.de)

\* Symbols taken from english version of the Regulation 2015/1095

\*\* Since condensing units are non functional systems Cdc can not be determined by test. For this reason the default degradation coefficient Cdc (0.25) has to be applied according to EN 13215, Annex A.



## Performance Data Sheet according to EU Regulation 2015/1095

### SEPR Declaration Model: LH84E/4EES-6Y

#### Refrigerant: R507A

Item	Symbol*	Value		Unit
Evaporating temperature	t	-10	-35	°C
Annual electricity consumption	Q	24206	16604	kWh/a
Seasonal Energy Performance Ratio	SEPR	3,03	1,89	

#### Point A: Parameters at full load and ambient temperature 32°C

Rated cooling capacity	P <sub>A</sub>	11,91	4,21	kW
Rated power input	D <sub>A</sub>	5,54	3,03	kW
Rated COP	COP <sub>A</sub>	2,15	1,39	

#### Point B: Parameters at part load and ambient temperature 25°C

Declared cooling capacity	P <sub>B</sub>	13,38	4,77	kW
Declared power input	D <sub>B</sub>	5,26	2,97	kW
Declared COP	COP <sub>B</sub>	2,55	1,61	

#### Point C: Parameters at part load and ambient temperature 15°C

Declared cooling capacity	P <sub>C</sub>	15,42	5,55	kW
Declared power input	D <sub>C</sub>	4,76	2,82	kW
Declared COP	COP <sub>C</sub>	3,24	1,97	

#### Point D: Parameters at part load and ambient temperature 5°C

Declared cooling capacity	P <sub>D</sub>	17,39	6,29	kW
Declared power input	D <sub>D</sub>	4,17	2,59	kW
Declared COP	COP <sub>D</sub>	4,17	2,43	

#### Point E: Parameters at full load and ambient temperature 43°C (information only)

Declared cooling capacity	P <sub>E</sub>	9,56	3,31	kW
Declared power input	D <sub>E</sub>	5,87	3,04	kW
Declared COP	COP <sub>E</sub>	1,63	1,09	

#### Other items

Capacity control	—		
Reference temperature	Dew point temp.		
Suction gas temperature	toh	20°C	
Power voltage	Net	400V/50Hz	
Coefficient of degradation for units w/o capacity control**	Cdc	0,25	

Additional document: [Declaration of Conformity AC-500](#)

#### Contact details:

BITZER Kühlmaschinenbau GmbH  
Peter-Schaufel-Platz 1  
71065 Sindelfingen  
Deutschland  
Tel +49 (0) 70 31 932-0  
Fax +49 (0) 70 31 932-147  
E-Mail: [bitzer@bitzer.de](mailto:bitzer@bitzer.de)  
Internet: [www.bitzer.de](http://www.bitzer.de)

\* Symbols taken from english version of the Regulation 2015/1095

\*\* Since condensing units are non functional systems Cdc can not be determined by test. For this reason the default degradation coefficient Cdc (0.25) has to be applied according to EN 13215, Annex A.



## Performance Data Sheet according to EU Regulation 2015/1095

### SEPR Declaration Model: LH84E/4EES-6Y

#### Refrigerant: R448A

Item	Symbol*	Value		Unit
Evaporating temperature	t	-10	-35	°C
Annual electricity consumption	Q	22783	14424	kWh/a
Seasonal Energy Performance Ratio	SEPR	2,95	1,65	

#### Point A: Parameters at full load and ambient temperature 32°C

Rated cooling capacity	P <sub>A</sub>	10,94	3,20	kW
Rated power input	D <sub>A</sub>	5,12	2,52	kW
Rated COP	COP <sub>A</sub>	2,14	1,27	

#### Point B: Parameters at part load and ambient temperature 25°C

Declared cooling capacity	P <sub>B</sub>	12,12	3,69	kW
Declared power input	D <sub>B</sub>	4,84	2,50	kW
Declared COP	COP <sub>B</sub>	2,50	1,47	

#### Point C: Parameters at part load and ambient temperature 15°C

Declared cooling capacity	P <sub>C</sub>	13,81	4,39	kW
Declared power input	D <sub>C</sub>	4,37	2,46	kW
Declared COP	COP <sub>C</sub>	3,16	1,78	

#### Point D: Parameters at part load and ambient temperature 5°C

Declared cooling capacity	P <sub>D</sub>	15,48	5,03	kW
Declared power input	D <sub>D</sub>	3,86	2,45	kW
Declared COP	COP <sub>D</sub>	4,01	2,06	

#### Point E: Parameters at full load and ambient temperature 43°C (information only)

Declared cooling capacity	P <sub>E</sub>	9,11	2,48	kW
Declared power input	D <sub>E</sub>	5,45	2,49	kW
Declared COP	COP <sub>E</sub>	1,67	1,00	

#### Other items

Capacity control	—		
Reference temperature	Dew point temp.		
Suction gas temperature	toh	20°C	
Power voltage	Net	400V/50Hz	
Coefficient of degradation for units w/o capacity control**	Cdc	0,25	

Additional document: [Declaration of Conformity AC-500](#)

#### Contact details:

BITZER Kühlmaschinenbau GmbH  
Peter-Schaufler-Platz 1  
71065 Sindelfingen  
Deutschland  
Tel +49 (0) 70 31 932-0  
Fax +49 (0) 70 31 932-147  
E-Mail: [bitzer@bitzer.de](mailto:bitzer@bitzer.de)  
Internet: [www.bitzer.de](http://www.bitzer.de)

\* Symbols taken from english version of the Regulation 2015/1095

\*\* Since condensing units are non functional systems Cdc can not be determined by test. For this reason the default degradation coefficient Cdc (0.25) has to be applied according to EN 13215, Annex A.



## Performance Data Sheet according to EU Regulation 2015/1095

### SEPR Declaration Model: LH84E/4EES-6Y

#### Refrigerant: R449A

Item	Symbol*	Value		Unit
Evaporating temperature	t	-10	-35	°C
Annual electricity consumption	Q	22750	14415	kWh/a
Seasonal Energy Performance Ratio	SEPR	2,94	1,65	

#### Point A: Parameters at full load and ambient temperature 32°C

Rated cooling capacity	P <sub>A</sub>	10,89	3,20	kW
Rated power input	D <sub>A</sub>	5,12	2,52	kW
Rated COP	COP <sub>A</sub>	2,13	1,27	

#### Point B: Parameters at part load and ambient temperature 25°C

Declared cooling capacity	P <sub>B</sub>	12,07	3,69	kW
Declared power input	D <sub>B</sub>	4,84	2,50	kW
Declared COP	COP <sub>B</sub>	2,49	1,47	

#### Point C: Parameters at part load and ambient temperature 15°C

Declared cooling capacity	P <sub>C</sub>	13,76	4,39	kW
Declared power input	D <sub>C</sub>	4,37	2,46	kW
Declared COP	COP <sub>C</sub>	3,15	1,78	

#### Point D: Parameters at part load and ambient temperature 5°C

Declared cooling capacity	P <sub>D</sub>	15,43	5,04	kW
Declared power input	D <sub>D</sub>	3,86	2,45	kW
Declared COP	COP <sub>D</sub>	4,00	2,06	

#### Point E: Parameters at full load and ambient temperature 43°C (information only)

Declared cooling capacity	P <sub>E</sub>	9,06	2,48	kW
Declared power input	D <sub>E</sub>	5,45	2,49	kW
Declared COP	COP <sub>E</sub>	1,66	1,00	

#### Other items

Capacity control	—		
Reference temperature	Dew point temp.		
Suction gas temperature	toh	20°C	
Power voltage	Net	400V/50Hz	
Coefficient of degradation for units w/o capacity control**	Cdc	0,25	

Additional document: [Declaration of Conformity AC-500](#)

#### Contact details:

BITZER Kühlmaschinenbau GmbH  
Peter-Schaufler-Platz 1  
71065 Sindelfingen  
Deutschland  
Tel +49 (0) 70 31 932-0  
Fax +49 (0) 70 31 932-147  
E-Mail: [bitzer@bitzer.de](mailto:bitzer@bitzer.de)  
Internet: [www.bitzer.de](http://www.bitzer.de)

\* Symbols taken from english version of the Regulation 2015/1095

\*\* Since condensing units are non functional systems Cdc can not be determined by test. For this reason the default degradation coefficient Cdc (0.25) has to be applied according to EN 13215, Annex A.



## Performance Data Sheet according to EU Regulation 2015/1095

### SEPR Declaration Model: LH84E/4EES-6Y

#### Refrigerant: R450A

Item	Symbol*	Value	Unit
Evaporating temperature	t	-10	°C
Annual electricity consumption	Q	12182	kWh/a
Seasonal Energy Performance Ratio	SEPR	3,31	

#### Point A: Parameters at full load and ambient temperature 32°C

Rated cooling capacity	P <sub>A</sub>	6,57		kW
Rated power input	D <sub>A</sub>	2,73		kW
<b>Rated COP</b>	<b>COP<sub>A</sub></b>	<b>2,40</b>		

#### Point B: Parameters at part load and ambient temperature 25°C

Declared cooling capacity	P <sub>B</sub>	7,20		kW
Declared power input	D <sub>B</sub>	2,57		kW
<b>Declared COP</b>	<b>COP<sub>B</sub></b>	<b>2,80</b>		

#### Point C: Parameters at part load and ambient temperature 15°C

Declared cooling capacity	P <sub>C</sub>	8,09		kW
Declared power input	D <sub>C</sub>	2,30		kW
<b>Declared COP</b>	<b>COP<sub>C</sub></b>	<b>3,52</b>		

#### Point D: Parameters at part load and ambient temperature 5°C

Declared cooling capacity	P <sub>D</sub>	8,97		kW
Declared power input	D <sub>D</sub>	1,99		kW
<b>Declared COP</b>	<b>COP<sub>D</sub></b>	<b>4,50</b>		

#### Point E: Parameters at full load and ambient temperature 43°C (information only)

Declared cooling capacity	P <sub>E</sub>	5,59		kW
Declared power input	D <sub>E</sub>	2,94		kW
<b>Declared COP</b>	<b>COP<sub>E</sub></b>	<b>1,90</b>		

#### Other items

Capacity control	—		
Reference temperature	Dew point temp.		
Suction gas temperature	toh	20°C	
Power voltage	Net	400V/50Hz	
Coefficient of degradation for units w/o capacity control**	Cdc	0,25	

Additional document: [Declaration of Conformity AC-500](#)

#### Contact details:

BITZER Kühlmaschinenbau GmbH  
Peter-Schaufler-Platz 1  
71065 Sindelfingen  
Deutschland  
Tel +49 (0) 70 31 932-0  
Fax +49 (0) 70 31 932-147  
E-Mail: [bitzer@bitzer.de](mailto:bitzer@bitzer.de)  
Internet: [www.bitzer.de](http://www.bitzer.de)

\* Symbols taken from english version of the Regulation 2015/1095

\*\* Since condensing units are non functional systems Cdc can not be determined by test. For this reason the default degradation coefficient Cdc (0.25) has to be applied according to EN 13215, Annex A.



## Performance Data Sheet according to EU Regulation 2015/1095

### SEPR Declaration Model: LH84E/4EES-6Y

#### Refrigerant: R513A

Item	Symbol*	Value	Unit
Evaporating temperature	t	-10	°C
Annual electricity consumption	Q	14332	kWh/a
Seasonal Energy Performance Ratio	SEPR	3,37	

#### Point A: Parameters at full load and ambient temperature 32°C

Rated cooling capacity	P <sub>A</sub>	7,86		kW
Rated power input	D <sub>A</sub>	3,22		kW
<b>Rated COP</b>	<b>COP<sub>A</sub></b>	<b>2,44</b>		

#### Point B: Parameters at part load and ambient temperature 25°C

Declared cooling capacity	P <sub>B</sub>	8,64		kW
Declared power input	D <sub>B</sub>	3,03		kW
<b>Declared COP</b>	<b>COP<sub>B</sub></b>	<b>2,85</b>		

#### Point C: Parameters at part load and ambient temperature 15°C

Declared cooling capacity	P <sub>C</sub>	9,75		kW
Declared power input	D <sub>C</sub>	2,72		kW
<b>Declared COP</b>	<b>COP<sub>C</sub></b>	<b>3,58</b>		

#### Point D: Parameters at part load and ambient temperature 5°C

Declared cooling capacity	P <sub>D</sub>	10,84		kW
Declared power input	D <sub>D</sub>	2,36		kW
<b>Declared COP</b>	<b>COP<sub>D</sub></b>	<b>4,59</b>		

#### Point E: Parameters at full load and ambient temperature 43°C (information only)

Declared cooling capacity	P <sub>E</sub>	6,63		kW
Declared power input	D <sub>E</sub>	3,46		kW
<b>Declared COP</b>	<b>COP<sub>E</sub></b>	<b>1,92</b>		

#### Other items

Capacity control	—		
Reference temperature	Dew point temp.		
Suction gas temperature	toh	20°C	
Power voltage	Net	400V/50Hz	
Coefficient of degradation for units w/o capacity control**	Cdc	0,25	

Additional document: [Declaration of Conformity AC-500](#)

#### Contact details:

BITZER Kühlmaschinenbau GmbH  
Peter-Schaufler-Platz 1  
71065 Sindelfingen  
Deutschland  
Tel +49 (0) 70 31 932-0  
Fax +49 (0) 70 31 932-147  
E-Mail: [bitzer@bitzer.de](mailto:bitzer@bitzer.de)  
Internet: [www.bitzer.de](http://www.bitzer.de)

\* Symbols taken from english version of the Regulation 2015/1095

\*\* Since condensing units are non functional systems Cdc can not be determined by test. For this reason the default degradation coefficient Cdc (0.25) has to be applied according to EN 13215, Annex A.



## Performance Data Sheet according to EU Regulation 2015/1095

### SEPR Declaration Model: LH84E/4EES-6Y

#### Refrigerant: R1234yf

Item	Symbol*	Value	Unit
Evaporating temperature	t	-10	°C
Annual electricity consumption	Q	13867	kWh/a
Seasonal Energy Performance Ratio	SEPR	3,35	

#### Point A: Parameters at full load and ambient temperature 32°C

Rated cooling capacity	P <sub>A</sub>	7,56		kW
Rated power input	D <sub>A</sub>	3,15		kW
<b>Rated COP</b>	<b>COP<sub>A</sub></b>	<b>2,40</b>		

#### Point B: Parameters at part load and ambient temperature 25°C

Declared cooling capacity	P <sub>B</sub>	8,33		kW
Declared power input	D <sub>B</sub>	2,96		kW
<b>Declared COP</b>	<b>COP<sub>B</sub></b>	<b>2,82</b>		

#### Point C: Parameters at part load and ambient temperature 15°C

Declared cooling capacity	P <sub>C</sub>	9,43		kW
Declared power input	D <sub>C</sub>	2,64		kW
<b>Declared COP</b>	<b>COP<sub>C</sub></b>	<b>3,57</b>		

#### Point D: Parameters at part load and ambient temperature 5°C

Declared cooling capacity	P <sub>D</sub>	10,52		kW
Declared power input	D <sub>D</sub>	2,29		kW
<b>Declared COP</b>	<b>COP<sub>D</sub></b>	<b>4,58</b>		

#### Point E: Parameters at full load and ambient temperature 43°C (information only)

Declared cooling capacity	P <sub>E</sub>	6,36		kW
Declared power input	D <sub>E</sub>	3,40		kW
<b>Declared COP</b>	<b>COP<sub>E</sub></b>	<b>1,87</b>		

#### Other items

Capacity control	—		
Reference temperature	Dew point temp.		
Suction gas temperature	toh	20°C	
Power voltage	Net	400V/50Hz	
Coefficient of degradation for units w/o capacity control**	Cdc	0,25	

Additional document: [Declaration of Conformity AC-500](#)

#### Contact details:

BITZER Kühlmaschinenbau GmbH  
Peter-Schaufler-Platz 1  
71065 Sindelfingen  
Deutschland  
Tel +49 (0) 70 31 932-0  
Fax +49 (0) 70 31 932-147  
E-Mail: [bitzer@bitzer.de](mailto:bitzer@bitzer.de)  
Internet: [www.bitzer.de](http://www.bitzer.de)

\* Symbols taken from english version of the Regulation 2015/1095

\*\* Since condensing units are non functional systems Cdc can not be determined by test. For this reason the default degradation coefficient Cdc (0.25) has to be applied according to EN 13215, Annex A.



## Performance Data Sheet according to EU Regulation 2015/1095

### SEPR Declaration Model: LH84E/4EES-6Y

#### Refrigerant: R1234ze

Item	Symbol*	Value	Unit
Evaporating temperature	t	-10	°C
Annual electricity consumption	Q	10831	kWh/a
Seasonal Energy Performance Ratio	SEPR	3,29	

#### Point A: Parameters at full load and ambient temperature 32°C

Rated cooling capacity	P <sub>A</sub>	5,80		kW
Rated power input	D <sub>A</sub>	2,38		kW
<b>Rated COP</b>	<b>COP<sub>A</sub></b>	<b>2,43</b>		

#### Point B: Parameters at part load and ambient temperature 25°C

Declared cooling capacity	P <sub>B</sub>	6,34		kW
Declared power input	D <sub>B</sub>	2,24		kW
<b>Declared COP</b>	<b>COP<sub>B</sub></b>	<b>2,83</b>		

#### Point C: Parameters at part load and ambient temperature 15°C

Declared cooling capacity	P <sub>C</sub>	7,12		kW
Declared power input	D <sub>C</sub>	2,01		kW
<b>Declared COP</b>	<b>COP<sub>C</sub></b>	<b>3,55</b>		

#### Point D: Parameters at part load and ambient temperature 5°C

Declared cooling capacity	P <sub>D</sub>	7,76		kW
Declared power input	D <sub>D</sub>	1,79		kW
<b>Declared COP</b>	<b>COP<sub>D</sub></b>	<b>4,34</b>		

#### Point E: Parameters at full load and ambient temperature 43°C (information only)

Declared cooling capacity	P <sub>E</sub>	4,95		kW
Declared power input	D <sub>E</sub>	2,57		kW
<b>Declared COP</b>	<b>COP<sub>E</sub></b>	<b>1,93</b>		

#### Other items

Capacity control	—		
Reference temperature	Dew point temp.		
Suction gas temperature	toh	20°C	
Power voltage	Net	400V/50Hz	
Coefficient of degradation for units w/o capacity control**	Cdc	0,25	

Additional document: [Declaration of Conformity AC-500](#)

#### Contact details:

BITZER Kühlmaschinenbau GmbH  
Peter-Schaufler-Platz 1  
71065 Sindelfingen  
Deutschland  
Tel +49 (0) 70 31 932-0  
Fax +49 (0) 70 31 932-147  
E-Mail: [bitzer@bitzer.de](mailto:bitzer@bitzer.de)  
Internet: [www.bitzer.de](http://www.bitzer.de)

\* Symbols taken from english version of the Regulation 2015/1095

\*\* Since condensing units are non functional systems Cdc can not be determined by test. For this reason the default degradation coefficient Cdc (0.25) has to be applied according to EN 13215, Annex A.