



## Performance Data Sheet according to EU Regulation 2015/1095

### SEPR Declaration Model: LH84E/4FES-3Y

#### Refrigerant: R134a

Item	Symbol*	Value	Unit
Evaporating temperature	t	-10	°C
Annual electricity consumption	Q	10650	kWh/a
Seasonal Energy Performance Ratio	SEPR	3,35	

#### Point A: Parameters at full load and ambient temperature 32°C

Rated cooling capacity	P <sub>A</sub>	5,81		kW
Rated power input	D <sub>A</sub>	2,37		kW
<b>Rated COP</b>	<b>COP<sub>A</sub></b>	<b>2,45</b>		

#### Point B: Parameters at part load and ambient temperature 25°C

Declared cooling capacity	P <sub>B</sub>	6,39		kW
Declared power input	D <sub>B</sub>	2,24		kW
<b>Declared COP</b>	<b>COP<sub>B</sub></b>	<b>2,85</b>		

#### Point C: Parameters at part load and ambient temperature 15°C

Declared cooling capacity	P <sub>C</sub>	7,21		kW
Declared power input	D <sub>C</sub>	2,01		kW
<b>Declared COP</b>	<b>COP<sub>C</sub></b>	<b>3,58</b>		

#### Point D: Parameters at part load and ambient temperature 5°C

Declared cooling capacity	P <sub>D</sub>	7,96		kW
Declared power input	D <sub>D</sub>	1,76		kW
<b>Declared COP</b>	<b>COP<sub>D</sub></b>	<b>4,52</b>		

#### Point E: Parameters at full load and ambient temperature 43°C (information only)

Declared cooling capacity	P <sub>E</sub>	4,88		kW
Declared power input	D <sub>E</sub>	2,52		kW
<b>Declared COP</b>	<b>COP<sub>E</sub></b>	<b>1,93</b>		

#### Other items

Capacity control	—		
Reference temperature	Dew point temp.		
Suction gas temperature	toh	20°C	
Power voltage	Net	400V/50Hz	
Coefficient of degradation for units w/o capacity control**	Cdc	0,25	

Additional document: [Declaration of Conformity AC-500](#)

#### Contact details:

BITZER Kühlmaschinenbau GmbH  
Peter-Schaufel-Platz 1  
71065 Sindelfingen  
Deutschland  
Tel +49 (0) 70 31 932-0  
Fax +49 (0) 70 31 932-147  
E-Mail: [bitzer@bitzer.de](mailto:bitzer@bitzer.de)  
Internet: [www.bitzer.de](http://www.bitzer.de)

\* Symbols taken from english version of the Regulation 2015/1095

\*\* Since condensing units are non functional systems Cdc can not be determined by test. For this reason the default degradation coefficient Cdc (0.25) has to be applied according to EN 13215, Annex A.



## Performance Data Sheet according to EU Regulation 2015/1095

### SEPR Declaration Model: LH84E/4FES-3Y

#### Refrigerant: R404A

Item	Symbol*	Value		Unit
Evaporating temperature	t	-10	-35	°C
Annual electricity consumption	Q	18896	13961	kWh/a
Seasonal Energy Performance Ratio	SEPR	3,18	1,78	

#### Point A: Parameters at full load and ambient temperature 32°C

Rated cooling capacity	P <sub>A</sub>	9,76	3,34	kW
Rated power input	D <sub>A</sub>	4,46	2,56	kW
Rated COP	COP <sub>A</sub>	2,19	1,30	

#### Point B: Parameters at part load and ambient temperature 25°C

Declared cooling capacity	P <sub>B</sub>	10,91	3,74	kW
Declared power input	D <sub>B</sub>	4,18	2,48	kW
Declared COP	COP <sub>B</sub>	2,61	1,51	

#### Point C: Parameters at part load and ambient temperature 15°C

Declared cooling capacity	P <sub>C</sub>	12,50	4,28	kW
Declared power input	D <sub>C</sub>	3,70	2,32	kW
Declared COP	COP <sub>C</sub>	3,37	1,85	

#### Point D: Parameters at part load and ambient temperature 5°C

Declared cooling capacity	P <sub>D</sub>	13,99	4,76	kW
Declared power input	D <sub>D</sub>	3,14	2,09	kW
Declared COP	COP <sub>D</sub>	4,45	2,28	

#### Point E: Parameters at full load and ambient temperature 43°C (information only)

Declared cooling capacity	P <sub>E</sub>	7,89	2,67	kW
Declared power input	D <sub>E</sub>	4,79	2,60	kW
Declared COP	COP <sub>E</sub>	1,65	1,03	

#### Other items

Capacity control	—		
Reference temperature	Dew point temp.		
Suction gas temperature	toh	20°C	
Power voltage	Net	400V/50Hz	
Coefficient of degradation for units w/o capacity control**	Cdc	0,25	

Additional document: [Declaration of Conformity AC-500](#)

#### Contact details:

BITZER Kühlmaschinenbau GmbH  
Peter-Schaufel-Platz 1  
71065 Sindelfingen  
Deutschland  
Tel +49 (0) 70 31 932-0  
Fax +49 (0) 70 31 932-147  
E-Mail: [bitzer@bitzer.de](mailto:bitzer@bitzer.de)  
Internet: [www.bitzer.de](http://www.bitzer.de)

\* Symbols taken from english version of the Regulation 2015/1095

\*\* Since condensing units are non functional systems Cdc can not be determined by test. For this reason the default degradation coefficient Cdc (0.25) has to be applied according to EN 13215, Annex A.



## Performance Data Sheet according to EU Regulation 2015/1095

### SEPR Declaration Model: LH84E/4FES-3Y

#### Refrigerant: R407A

Condensing unit with the selected refrigerant at low temperature application (LT) is only intended for deliveries outside the EU. For EU suitable condensing units, see Declaration of Conformity AC-500.

Item	Symbol*	Value	Unit
Evaporating temperature	t	-10	°C
Annual electricity consumption	Q	17765	kWh/a
Seasonal Energy Performance Ratio	SEPR	3,09	

#### Point A: Parameters at full load and ambient temperature 32°C

Rated cooling capacity	P <sub>A</sub>	8,92		kW
Rated power input	D <sub>A</sub>	4,06		kW
Rated COP	COP <sub>A</sub>	2,20		

#### Point B: Parameters at part load and ambient temperature 25°C

Declared cooling capacity	P <sub>B</sub>	9,86		kW
Declared power input	D <sub>B</sub>	3,80		kW
Declared COP	COP <sub>B</sub>	2,59		

#### Point C: Parameters at part load and ambient temperature 15°C

Declared cooling capacity	P <sub>C</sub>	11,21		kW
Declared power input	D <sub>C</sub>	3,40		kW
Declared COP	COP <sub>C</sub>	3,30		

#### Point D: Parameters at part load and ambient temperature 5°C

Declared cooling capacity	P <sub>D</sub>	12,53		kW
Declared power input	D <sub>D</sub>	2,97		kW
Declared COP	COP <sub>D</sub>	4,22		

#### Point E: Parameters at full load and ambient temperature 43°C (information only)

Declared cooling capacity	P <sub>E</sub>	7,47		kW
Declared power input	D <sub>E</sub>	4,38		kW
Declared COP	COP <sub>E</sub>	1,71		

#### Other items

Capacity control	—		
Reference temperature	Dew point temp.		
Suction gas temperature	toh	20°C	
Power voltage	Net	400V/50Hz	
Coefficient of degradation for units w/o capacity control**	Cdc	0,25	

Additional document: [Declaration of Conformity AC-500](#)

#### Contact details:

BITZER Kühlmaschinenbau GmbH  
Peter-Schaufler-Platz 1  
71065 Sindelfingen  
Deutschland  
Tel +49 (0) 70 31 932-0  
Fax +49 (0) 70 31 932-147  
E-Mail: [bitzer@bitzer.de](mailto:bitzer@bitzer.de)  
Internet: [www.bitzer.de](http://www.bitzer.de)

\* Symbols taken from english version of the Regulation 2015/1095

\*\* Since condensing units are non functional systems Cdc can not be determined by test. For this reason the default degradation coefficient Cdc (0.25) has to be applied according to EN 13215, Annex A.



## Performance Data Sheet according to EU Regulation 2015/1095

### SEPR Declaration Model: LH84E/4FES-3Y

#### Refrigerant: R407C

Item	Symbol*	Value	Unit
Evaporating temperature	t	-10	°C
Annual electricity consumption	Q	16219	kWh/a
Seasonal Energy Performance Ratio	SEPR	3,11	

#### Point A: Parameters at full load and ambient temperature 32°C

Rated cooling capacity	P <sub>A</sub>	8,22		kW
Rated power input	D <sub>A</sub>	3,63		kW
<b>Rated COP</b>	<b>COP<sub>A</sub></b>	<b>2,26</b>		

#### Point B: Parameters at part load and ambient temperature 25°C

Declared cooling capacity	P <sub>B</sub>	9,11		kW
Declared power input	D <sub>B</sub>	3,45		kW
<b>Declared COP</b>	<b>COP<sub>B</sub></b>	<b>2,64</b>		

#### Point C: Parameters at part load and ambient temperature 15°C

Declared cooling capacity	P <sub>C</sub>	10,36		kW
Declared power input	D <sub>C</sub>	3,12		kW
<b>Declared COP</b>	<b>COP<sub>C</sub></b>	<b>3,32</b>		

#### Point D: Parameters at part load and ambient temperature 5°C

Declared cooling capacity	P <sub>D</sub>	11,60		kW
Declared power input	D <sub>D</sub>	2,73		kW
<b>Declared COP</b>	<b>COP<sub>D</sub></b>	<b>4,25</b>		

#### Point E: Parameters at full load and ambient temperature 43°C (information only)

Declared cooling capacity	P <sub>E</sub>	6,81		kW
Declared power input	D <sub>E</sub>	3,82		kW
<b>Declared COP</b>	<b>COP<sub>E</sub></b>	<b>1,78</b>		

#### Other items

Capacity control	—		
Reference temperature	Dew point temp.		
Suction gas temperature	toh	20°C	
Power voltage	Net	400V/50Hz	
Coefficient of degradation for units w/o capacity control**	Cdc	0,25	

Additional document: [Declaration of Conformity AC-500](#)

#### Contact details:

BITZER Kühlmaschinenbau GmbH  
Peter-Schaufel-Platz 1  
71065 Sindelfingen  
Deutschland  
Tel +49 (0) 70 31 932-0  
Fax +49 (0) 70 31 932-147  
E-Mail: [bitzer@bitzer.de](mailto:bitzer@bitzer.de)  
Internet: [www.bitzer.de](http://www.bitzer.de)

\* Symbols taken from english version of the Regulation 2015/1095

\*\* Since condensing units are non functional systems Cdc can not be determined by test. For this reason the default degradation coefficient Cdc (0.25) has to be applied according to EN 13215, Annex A.



## Performance Data Sheet according to EU Regulation 2015/1095

### SEPR Declaration Model: LH84E/4FES-3Y

#### Refrigerant: R407F

Item	Symbol*	Value		Unit
Evaporating temperature	t	-10	-35	°C
Annual electricity consumption	Q	18649	12031	kWh/a
Seasonal Energy Performance Ratio	SEPR	3,06	1,61	

#### Point A: Parameters at full load and ambient temperature 32°C

Rated cooling capacity	P <sub>A</sub>	9,29	2,59	kW
Rated power input	D <sub>A</sub>	4,24	2,10	kW
Rated COP	COP <sub>A</sub>	2,19	1,23	

#### Point B: Parameters at part load and ambient temperature 25°C

Declared cooling capacity	P <sub>B</sub>	10,25	2,98	kW
Declared power input	D <sub>B</sub>	3,98	2,08	kW
Declared COP	COP <sub>B</sub>	2,58	1,43	

#### Point C: Parameters at part load and ambient temperature 15°C

Declared cooling capacity	P <sub>C</sub>	11,62	3,54	kW
Declared power input	D <sub>C</sub>	3,55	2,04	kW
Declared COP	COP <sub>C</sub>	3,27	1,73	

#### Point D: Parameters at part load and ambient temperature 5°C

Declared cooling capacity	P <sub>D</sub>	12,98	4,04	kW
Declared power input	D <sub>D</sub>	3,11	2,03	kW
Declared COP	COP <sub>D</sub>	4,18	1,99	

#### Point E: Parameters at full load and ambient temperature 43°C (information only)

Declared cooling capacity	P <sub>E</sub>	7,81	2,01	kW
Declared power input	D <sub>E</sub>	4,56	2,09	kW
Declared COP	COP <sub>E</sub>	1,71	0,96	

#### Other items

Capacity control	—		
Reference temperature	Dew point temp.		
Suction gas temperature	toh	20°C	
Power voltage	Net	400V/50Hz	
Coefficient of degradation for units w/o capacity control**	Cdc	0,25	

Additional document: [Declaration of Conformity AC-500](#)

#### Contact details:

BITZER Kühlmaschinenbau GmbH  
Peter-Schaufel-Platz 1  
71065 Sindelfingen  
Deutschland  
Tel +49 (0) 70 31 932-0  
Fax +49 (0) 70 31 932-147  
E-Mail: [bitzer@bitzer.de](mailto:bitzer@bitzer.de)  
Internet: [www.bitzer.de](http://www.bitzer.de)

\* Symbols taken from english version of the Regulation 2015/1095

\*\* Since condensing units are non functional systems Cdc can not be determined by test. For this reason the default degradation coefficient Cdc (0.25) has to be applied according to EN 13215, Annex A.



## Performance Data Sheet according to EU Regulation 2015/1095

### SEPR Declaration Model: LH84E/4FES-3Y

#### Refrigerant: R454C

Item	Symbol*	Value		Unit
Evaporating temperature	t	-10	-35	°C
Annual electricity consumption	Q	16408	11378	kWh/a
Seasonal Energy Performance Ratio	SEPR	3,02	1,52	

#### Point A: Parameters at full load and ambient temperature 32°C

Rated cooling capacity	P <sub>A</sub>	8,05	2,32	kW
Rated power input	D <sub>A</sub>	3,70	1,93	kW
Rated COP	COP <sub>A</sub>	2,18	1,20	

#### Point B: Parameters at part load and ambient temperature 25°C

Declared cooling capacity	P <sub>B</sub>	8,93	2,67	kW
Declared power input	D <sub>B</sub>	3,48	1,92	kW
Declared COP	COP <sub>B</sub>	2,56	1,39	

#### Point C: Parameters at part load and ambient temperature 15°C

Declared cooling capacity	P <sub>C</sub>	10,19	3,16	kW
Declared power input	D <sub>C</sub>	3,14	1,92	kW
Declared COP	COP <sub>C</sub>	3,24	1,65	

#### Point D: Parameters at part load and ambient temperature 5°C

Declared cooling capacity	P <sub>D</sub>	11,42	3,60	kW
Declared power input	D <sub>D</sub>	2,80	1,95	kW
Declared COP	COP <sub>D</sub>	4,08	1,85	

#### Point E: Parameters at full load and ambient temperature 43°C (information only)

Declared cooling capacity	P <sub>E</sub>	6,69	1,80	kW
Declared power input	D <sub>E</sub>	3,98	1,91	kW
Declared COP	COP <sub>E</sub>	1,68	0,94	

#### Other items

Capacity control	—		
Reference temperature	Dew point temp.		
Suction gas temperature	toh	20°C	
Power voltage	Net	400V/50Hz	
Coefficient of degradation for units w/o capacity control**	Cdc	0,25	

Additional document: [Declaration of Conformity AC-500](#)

#### Contact details:

BITZER Kühlmaschinenbau GmbH  
Peter-Schaufel-Platz 1  
71065 Sindelfingen  
Deutschland  
Tel +49 (0) 70 31 932-0  
Fax +49 (0) 70 31 932-147  
E-Mail: [bitzer@bitzer.de](mailto:bitzer@bitzer.de)  
Internet: [www.bitzer.de](http://www.bitzer.de)

\* Symbols taken from english version of the Regulation 2015/1095

\*\* Since condensing units are non functional systems Cdc can not be determined by test. For this reason the default degradation coefficient Cdc (0.25) has to be applied according to EN 13215, Annex A.



## Performance Data Sheet according to EU Regulation 2015/1095

### SEPR Declaration Model: LH84E/4FES-3Y

#### Refrigerant: R455A

Item	Symbol*	Value	Unit
Evaporating temperature	t	-10	°C
Annual electricity consumption	Q	18093	kWh/a
Seasonal Energy Performance Ratio	SEPR	2,67	1,45

#### Point A: Parameters at full load and ambient temperature 32°C

Rated cooling capacity	P <sub>A</sub>	7,87	2,22	kW
Rated power input	D <sub>A</sub>	4,09	2,03	kW
<b>Rated COP</b>	<b>COP<sub>A</sub></b>	<b>1,93</b>	<b>1,09</b>	

#### Point B: Parameters at part load and ambient temperature 25°C

Declared cooling capacity	P <sub>B</sub>	8,80	2,58	kW
Declared power input	D <sub>B</sub>	3,88	2,03	kW
<b>Declared COP</b>	<b>COP<sub>B</sub></b>	<b>2,27</b>	<b>1,27</b>	

#### Point C: Parameters at part load and ambient temperature 15°C

Declared cooling capacity	P <sub>C</sub>	10,14	3,12	kW
Declared power input	D <sub>C</sub>	3,53	2,01	kW
<b>Declared COP</b>	<b>COP<sub>C</sub></b>	<b>2,87</b>	<b>1,56</b>	

#### Point D: Parameters at part load and ambient temperature 5°C

Declared cooling capacity	P <sub>D</sub>	11,47	3,65	kW
Declared power input	D <sub>D</sub>	3,14	1,99	kW
<b>Declared COP</b>	<b>COP<sub>D</sub></b>	<b>3,65</b>	<b>1,83</b>	

#### Point E: Parameters at full load and ambient temperature 43°C (information only)

Declared cooling capacity	P <sub>E</sub>	--	--	kW
Declared power input	D <sub>E</sub>	--	--	kW
<b>Declared COP</b>	<b>COP<sub>E</sub></b>	<b>--</b>	<b>--</b>	

#### Other items

Capacity control	—		
Reference temperature	Dew point temp.		
Suction gas temperature	toh	20°C	
Power voltage	Net	400V/50Hz	
Coefficient of degradation for units w/o capacity control**	Cdc	0,25	

Additional document: [Declaration of Conformity AC-500](#)

#### Contact details:

BITZER Kühlmaschinenbau GmbH  
Peter-Schaufel-Platz 1  
71065 Sindelfingen  
Deutschland  
Tel +49 (0) 70 31 932-0  
Fax +49 (0) 70 31 932-147  
E-Mail: [bitzer@bitzer.de](mailto:bitzer@bitzer.de)  
Internet: [www.bitzer.de](http://www.bitzer.de)

\* Symbols taken from english version of the Regulation 2015/1095

\*\* Since condensing units are non functional systems Cdc can not be determined by test. For this reason the default degradation coefficient Cdc (0.25) has to be applied according to EN 13215, Annex A.



## Performance Data Sheet according to EU Regulation 2015/1095

### SEPR Declaration Model: LH84E/4FES-3Y

#### Refrigerant: R507A

Item	Symbol*	Value		Unit
Evaporating temperature	t	-10	-35	°C
Annual electricity consumption	Q	18941	13958	kWh/a
Seasonal Energy Performance Ratio	SEPR	3,24	1,86	

#### Point A: Parameters at full load and ambient temperature 32°C

Rated cooling capacity	P <sub>A</sub>	10,00	3,49	kW
Rated power input	D <sub>A</sub>	4,47	2,56	kW
Rated COP	COP <sub>A</sub>	2,24	1,36	

#### Point B: Parameters at part load and ambient temperature 25°C

Declared cooling capacity	P <sub>B</sub>	11,19	3,91	kW
Declared power input	D <sub>B</sub>	4,19	2,49	kW
Declared COP	COP <sub>B</sub>	2,67	1,57	

#### Point C: Parameters at part load and ambient temperature 15°C

Declared cooling capacity	P <sub>C</sub>	12,84	4,48	kW
Declared power input	D <sub>C</sub>	3,72	2,32	kW
Declared COP	COP <sub>C</sub>	3,45	1,93	

#### Point D: Parameters at part load and ambient temperature 5°C

Declared cooling capacity	P <sub>D</sub>	14,40	4,99	kW
Declared power input	D <sub>D</sub>	3,17	2,09	kW
Declared COP	COP <sub>D</sub>	4,55	2,39	

#### Point E: Parameters at full load and ambient temperature 43°C (information only)

Declared cooling capacity	P <sub>E</sub>	8,05	2,79	kW
Declared power input	D <sub>E</sub>	4,79	2,60	kW
Declared COP	COP <sub>E</sub>	1,68	1,07	

#### Other items

Capacity control	—		
Reference temperature	Dew point temp.		
Suction gas temperature	toh	20°C	
Power voltage	Net	400V/50Hz	
Coefficient of degradation for units w/o capacity control**	Cdc	0,25	

Additional document: [Declaration of Conformity AC-500](#)

#### Contact details:

BITZER Kühlmaschinenbau GmbH  
Peter-Schaufel-Platz 1  
71065 Sindelfingen  
Deutschland  
Tel +49 (0) 70 31 932-0  
Fax +49 (0) 70 31 932-147  
E-Mail: [bitzer@bitzer.de](mailto:bitzer@bitzer.de)  
Internet: [www.bitzer.de](http://www.bitzer.de)

\* Symbols taken from english version of the Regulation 2015/1095

\*\* Since condensing units are non functional systems Cdc can not be determined by test. For this reason the default degradation coefficient Cdc (0.25) has to be applied according to EN 13215, Annex A.



## Performance Data Sheet according to EU Regulation 2015/1095

### SEPR Declaration Model: LH84E/4FES-3Y

#### Refrigerant: R448A

Item	Symbol*	Value	Unit
Evaporating temperature	t	-10	°C
Annual electricity consumption	Q	18079	kWh/a
Seasonal Energy Performance Ratio	SEPR	3,09	1,61

#### Point A: Parameters at full load and ambient temperature 32°C

Rated cooling capacity	P <sub>A</sub>	9,09	2,62	kW
Rated power input	D <sub>A</sub>	4,13	2,11	kW
Rated COP	COP <sub>A</sub>	2,20	1,24	

#### Point B: Parameters at part load and ambient temperature 25°C

Declared cooling capacity	P <sub>B</sub>	10,05	3,01	kW
Declared power input	D <sub>B</sub>	3,87	2,09	kW
Declared COP	COP <sub>B</sub>	2,60	1,44	

#### Point C: Parameters at part load and ambient temperature 15°C

Declared cooling capacity	P <sub>C</sub>	11,43	3,57	kW
Declared power input	D <sub>C</sub>	3,46	2,05	kW
Declared COP	COP <sub>C</sub>	3,30	1,74	

#### Point D: Parameters at part load and ambient temperature 5°C

Declared cooling capacity	P <sub>D</sub>	12,78	4,08	kW
Declared power input	D <sub>D</sub>	3,02	2,04	kW
Declared COP	COP <sub>D</sub>	4,22	2,00	

#### Point E: Parameters at full load and ambient temperature 43°C (information only)

Declared cooling capacity	P <sub>E</sub>	7,60	2,04	kW
Declared power input	D <sub>E</sub>	4,44	2,10	kW
Declared COP	COP <sub>E</sub>	1,71	0,97	

#### Other items

Capacity control	—		
Reference temperature	Dew point temp.		
Suction gas temperature	toh	20°C	
Power voltage	Net	400V/50Hz	
Coefficient of degradation for units w/o capacity control**	Cdc	0,25	

Additional document: [Declaration of Conformity AC-500](#)

#### Contact details:

BITZER Kühlmaschinenbau GmbH  
Peter-Schaufel-Platz 1  
71065 Sindelfingen  
Deutschland  
Tel +49 (0) 70 31 932-0  
Fax +49 (0) 70 31 932-147  
E-Mail: [bitzer@bitzer.de](mailto:bitzer@bitzer.de)  
Internet: [www.bitzer.de](http://www.bitzer.de)

\* Symbols taken from english version of the Regulation 2015/1095

\*\* Since condensing units are non functional systems Cdc can not be determined by test. For this reason the default degradation coefficient Cdc (0.25) has to be applied according to EN 13215, Annex A.



## Performance Data Sheet according to EU Regulation 2015/1095

### SEPR Declaration Model: LH84E/4FES-3Y

#### Refrigerant: R449A

Item	Symbol*	Value	Unit
Evaporating temperature	t	-10	°C
Annual electricity consumption	Q	18052	kWh/a
Seasonal Energy Performance Ratio	SEPR	3,08	1,62

#### Point A: Parameters at full load and ambient temperature 32°C

Rated cooling capacity	P <sub>A</sub>	9,05	2,62	kW
Rated power input	D <sub>A</sub>	4,13	2,11	kW
Rated COP	COP <sub>A</sub>	2,19	1,24	

#### Point B: Parameters at part load and ambient temperature 25°C

Declared cooling capacity	P <sub>B</sub>	10,01	3,01	kW
Declared power input	D <sub>B</sub>	3,87	2,09	kW
Declared COP	COP <sub>B</sub>	2,59	1,44	

#### Point C: Parameters at part load and ambient temperature 15°C

Declared cooling capacity	P <sub>C</sub>	11,39	3,57	kW
Declared power input	D <sub>C</sub>	3,46	2,05	kW
Declared COP	COP <sub>C</sub>	3,29	1,74	

#### Point D: Parameters at part load and ambient temperature 5°C

Declared cooling capacity	P <sub>D</sub>	12,74	4,08	kW
Declared power input	D <sub>D</sub>	3,02	2,04	kW
Declared COP	COP <sub>D</sub>	4,21	2,00	

#### Point E: Parameters at full load and ambient temperature 43°C (information only)

Declared cooling capacity	P <sub>E</sub>	7,56	2,04	kW
Declared power input	D <sub>E</sub>	4,44	2,10	kW
Declared COP	COP <sub>E</sub>	1,70	0,97	

#### Other items

Capacity control	—		
Reference temperature	Dew point temp.		
Suction gas temperature	toh	20°C	
Power voltage	Net	400V/50Hz	
Coefficient of degradation for units w/o capacity control**	Cdc	0,25	

Additional document: [Declaration of Conformity AC-500](#)

#### Contact details:

BITZER Kühlmaschinenbau GmbH  
Peter-Schaufler-Platz 1  
71065 Sindelfingen  
Deutschland  
Tel +49 (0) 70 31 932-0  
Fax +49 (0) 70 31 932-147  
E-Mail: [bitzer@bitzer.de](mailto:bitzer@bitzer.de)  
Internet: [www.bitzer.de](http://www.bitzer.de)

\* Symbols taken from english version of the Regulation 2015/1095

\*\* Since condensing units are non functional systems Cdc can not be determined by test. For this reason the default degradation coefficient Cdc (0.25) has to be applied according to EN 13215, Annex A.



## Performance Data Sheet according to EU Regulation 2015/1095

### SEPR Declaration Model: LH84E/4FES-3Y

#### Refrigerant: R450A

Item	Symbol*	Value	Unit
Evaporating temperature	t	-10	°C
Annual electricity consumption	Q	9658	kWh/a
Seasonal Energy Performance Ratio	SEPR	3,24	

#### Point A: Parameters at full load and ambient temperature 32°C

Rated cooling capacity	P <sub>A</sub>	5,09		kW
Rated power input	D <sub>A</sub>	2,14		kW
<b>Rated COP</b>	<b>COP<sub>A</sub></b>	<b>2,38</b>		

#### Point B: Parameters at part load and ambient temperature 25°C

Declared cooling capacity	P <sub>B</sub>	5,61		kW
Declared power input	D <sub>B</sub>	2,02		kW
<b>Declared COP</b>	<b>COP<sub>B</sub></b>	<b>2,78</b>		

#### Point C: Parameters at part load and ambient temperature 15°C

Declared cooling capacity	P <sub>C</sub>	6,34		kW
Declared power input	D <sub>C</sub>	1,82		kW
<b>Declared COP</b>	<b>COP<sub>C</sub></b>	<b>3,49</b>		

#### Point D: Parameters at part load and ambient temperature 5°C

Declared cooling capacity	P <sub>D</sub>	6,95		kW
Declared power input	D <sub>D</sub>	1,61		kW
<b>Declared COP</b>	<b>COP<sub>D</sub></b>	<b>4,31</b>		

#### Point E: Parameters at full load and ambient temperature 43°C (information only)

Declared cooling capacity	P <sub>E</sub>	4,26		kW
Declared power input	D <sub>E</sub>	2,27		kW
<b>Declared COP</b>	<b>COP<sub>E</sub></b>	<b>1,87</b>		

#### Other items

Capacity control	—		
Reference temperature	Dew point temp.		
Suction gas temperature	toh	20°C	
Power voltage	Net	400V/50Hz	
Coefficient of degradation for units w/o capacity control**	Cdc	0,25	

Additional document: [Declaration of Conformity AC-500](#)

#### Contact details:

BITZER Kühlmaschinenbau GmbH  
Peter-Schaufler-Platz 1  
71065 Sindelfingen  
Deutschland  
Tel +49 (0) 70 31 932-0  
Fax +49 (0) 70 31 932-147  
E-Mail: [bitzer@bitzer.de](mailto:bitzer@bitzer.de)  
Internet: [www.bitzer.de](http://www.bitzer.de)

\* Symbols taken from english version of the Regulation 2015/1095

\*\* Since condensing units are non functional systems Cdc can not be determined by test. For this reason the default degradation coefficient Cdc (0.25) has to be applied according to EN 13215, Annex A.



## Performance Data Sheet according to EU Regulation 2015/1095

### SEPR Declaration Model: LH84E/4FES-3Y

#### Refrigerant: R513A

Item	Symbol*	Value	Unit
Evaporating temperature	t	-10	°C
Annual electricity consumption	Q	11120	kWh/a
Seasonal Energy Performance Ratio	SEPR	3,40	

#### Point A: Parameters at full load and ambient temperature 32°C

Rated cooling capacity	P <sub>A</sub>	6,16		kW
Rated power input	D <sub>A</sub>	2,50		kW
<b>Rated COP</b>	<b>COP<sub>A</sub></b>	<b>2,46</b>		

#### Point B: Parameters at part load and ambient temperature 25°C

Declared cooling capacity	P <sub>B</sub>	6,80		kW
Declared power input	D <sub>B</sub>	2,37		kW
<b>Declared COP</b>	<b>COP<sub>B</sub></b>	<b>2,88</b>		

#### Point C: Parameters at part load and ambient temperature 15°C

Declared cooling capacity	P <sub>C</sub>	7,70		kW
Declared power input	D <sub>C</sub>	2,13		kW
<b>Declared COP</b>	<b>COP<sub>C</sub></b>	<b>3,62</b>		

#### Point D: Parameters at part load and ambient temperature 5°C

Declared cooling capacity	P <sub>D</sub>	8,57		kW
Declared power input	D <sub>D</sub>	1,85		kW
<b>Declared COP</b>	<b>COP<sub>D</sub></b>	<b>4,65</b>		

#### Point E: Parameters at full load and ambient temperature 43°C (information only)

Declared cooling capacity	P <sub>E</sub>	5,12		kW
Declared power input	D <sub>E</sub>	2,65		kW
<b>Declared COP</b>	<b>COP<sub>E</sub></b>	<b>1,93</b>		

#### Other items

Capacity control	—		
Reference temperature	Dew point temp.		
Suction gas temperature	toh	20°C	
Power voltage	Net	400V/50Hz	
Coefficient of degradation for units w/o capacity control**	Cdc	0,25	

Additional document: [Declaration of Conformity AC-500](#)

#### Contact details:

BITZER Kühlmaschinenbau GmbH  
Peter-Schaufel-Platz 1  
71065 Sindelfingen  
Deutschland  
Tel +49 (0) 70 31 932-0  
Fax +49 (0) 70 31 932-147  
E-Mail: [bitzer@bitzer.de](mailto:bitzer@bitzer.de)  
Internet: [www.bitzer.de](http://www.bitzer.de)

\* Symbols taken from english version of the Regulation 2015/1095

\*\* Since condensing units are non functional systems Cdc can not be determined by test. For this reason the default degradation coefficient Cdc (0.25) has to be applied according to EN 13215, Annex A.



## Performance Data Sheet according to EU Regulation 2015/1095

### SEPR Declaration Model: LH84E/4FES-3Y

Refrigerant: R1234yf

Item	Symbol*	Value	Unit
Evaporating temperature	t	-10	°C
Annual electricity consumption	Q	10799	kWh/a
Seasonal Energy Performance Ratio	SEPR	3,38	

#### Point A: Parameters at full load and ambient temperature 32°C

Rated cooling capacity	P <sub>A</sub>	5,94		kW
Rated power input	D <sub>A</sub>	2,46		kW
<b>Rated COP</b>	<b>COP<sub>A</sub></b>	<b>2,42</b>		

#### Point B: Parameters at part load and ambient temperature 25°C

Declared cooling capacity	P <sub>B</sub>	6,58		kW
Declared power input	D <sub>B</sub>	2,32		kW
<b>Declared COP</b>	<b>COP<sub>B</sub></b>	<b>2,84</b>		

#### Point C: Parameters at part load and ambient temperature 15°C

Declared cooling capacity	P <sub>C</sub>	7,48		kW
Declared power input	D <sub>C</sub>	2,08		kW
<b>Declared COP</b>	<b>COP<sub>C</sub></b>	<b>3,60</b>		

#### Point D: Parameters at part load and ambient temperature 5°C

Declared cooling capacity	P <sub>D</sub>	8,37		kW
Declared power input	D <sub>D</sub>	1,80		kW
<b>Declared COP</b>	<b>COP<sub>D</sub></b>	<b>4,65</b>		

#### Point E: Parameters at full load and ambient temperature 43°C (information only)

Declared cooling capacity	P <sub>E</sub>	4,93		kW
Declared power input	D <sub>E</sub>	2,63		kW
<b>Declared COP</b>	<b>COP<sub>E</sub></b>	<b>1,88</b>		

#### Other items

Capacity control	—		
Reference temperature	Dew point temp.		
Suction gas temperature	toh	20°C	
Power voltage	Net	400V/50Hz	
Coefficient of degradation for units w/o capacity control**	Cdc	0,25	

Additional document: [Declaration of Conformity AC-500](#)

#### Contact details:

BITZER Kühlmaschinenbau GmbH  
Peter-Schaufel-Platz 1  
71065 Sindelfingen  
Deutschland  
Tel +49 (0) 70 31 932-0  
Fax +49 (0) 70 31 932-147  
E-Mail: [bitzer@bitzer.de](mailto:bitzer@bitzer.de)  
Internet: [www.bitzer.de](http://www.bitzer.de)

\* Symbols taken from english version of the Regulation 2015/1095

\*\* Since condensing units are non functional systems Cdc can not be determined by test. For this reason the default degradation coefficient Cdc (0.25) has to be applied according to EN 13215, Annex A.



## Performance Data Sheet according to EU Regulation 2015/1095

### COP Declaration Model: LH84E/4FES-3Y

**Refrigerant: R1234ze**

Item	Symbol*	Value	Unit
Evaporating temperature	t	-10	-35

#### Point A: Parameters at full load and ambient temperature 32°C

Rated cooling capacity	P <sub>A</sub>	4,41	kW
Rated power input	D <sub>A</sub>	1,87	kW
Rated COP	COP <sub>A</sub>	2,35	

#### Point B: Parameters at part load and ambient temperature 25°C (information only)

Declared cooling capacity	P <sub>B</sub>	4,84	kW
Declared power input	D <sub>B</sub>	1,77	kW
Declared COP	COP <sub>B</sub>	2,73	

#### Point E: Parameters at full load and ambient temperature 43°C (information only)

Declared cooling capacity	P <sub>E</sub>	3,73	kW
Declared power input	D <sub>E</sub>	2,00	kW
Declared COP	COP <sub>E</sub>	1,87	

#### Other items

Capacity control	—		
Reference temperature	Dew point temp.		
Suction gas temperature	toh	20°C	
Power voltage	Net	400V/50Hz	

*Additional document: Declaration of Conformity AC-500*

#### Contact details:

BITZER Kühlmaschinenbau GmbH  
Peter-Schaufler-Platz 1  
71065 Sindelfingen  
Deutschland  
Tel +49 (0) 70 31 932-0  
Fax +49 (0) 70 31 932-147  
E-Mail: bitzer@bitzer.de  
Internet: www.bitzer.de

\* Symbols taken from english version of the Regulation 2015/1095