



## Performance Data Sheet according to EU Regulation 2015/1095

### SEPR Declaration Model: LHL5E/4CES-6Y

#### Refrigerant: R134a

| Item                              | Symbol* | Value | Unit  |
|-----------------------------------|---------|-------|-------|
| Evaporating temperature           | t       | -10   | °C    |
| Annual electricity consumption    | Q       | 18019 | kWh/a |
| Seasonal Energy Performance Ratio | SEPR    | 3,49  |       |

#### Point A: Parameters at full load and ambient temperature 32°C

|                        |                        |             |  |    |
|------------------------|------------------------|-------------|--|----|
| Rated cooling capacity | P <sub>A</sub>         | 10,23       |  | kW |
| Rated power input      | D <sub>A</sub>         | 4,10        |  | kW |
| <b>Rated COP</b>       | <b>COP<sub>A</sub></b> | <b>2,50</b> |  |    |

#### Point B: Parameters at part load and ambient temperature 25°C

|                           |                        |             |  |    |
|---------------------------|------------------------|-------------|--|----|
| Declared cooling capacity | P <sub>B</sub>         | 11,22       |  | kW |
| Declared power input      | D <sub>B</sub>         | 3,85        |  | kW |
| <b>Declared COP</b>       | <b>COP<sub>B</sub></b> | <b>2,91</b> |  |    |

#### Point C: Parameters at part load and ambient temperature 15°C

|                           |                        |             |  |    |
|---------------------------|------------------------|-------------|--|----|
| Declared cooling capacity | P <sub>C</sub>         | 12,62       |  | kW |
| Declared power input      | D <sub>C</sub>         | 3,42        |  | kW |
| <b>Declared COP</b>       | <b>COP<sub>C</sub></b> | <b>3,69</b> |  |    |

#### Point D: Parameters at part load and ambient temperature 5°C

|                           |                        |             |  |    |
|---------------------------|------------------------|-------------|--|----|
| Declared cooling capacity | P <sub>D</sub>         | 14,02       |  | kW |
| Declared power input      | D <sub>D</sub>         | 2,92        |  | kW |
| <b>Declared COP</b>       | <b>COP<sub>D</sub></b> | <b>4,80</b> |  |    |

#### Point E: Parameters at full load and ambient temperature 43°C (information only)

|                           |                        |             |  |    |
|---------------------------|------------------------|-------------|--|----|
| Declared cooling capacity | P <sub>E</sub>         | 8,68        |  | kW |
| Declared power input      | D <sub>E</sub>         | 4,40        |  | kW |
| <b>Declared COP</b>       | <b>COP<sub>E</sub></b> | <b>1,97</b> |  |    |

#### Other items

|   |                 |           |  |
|---|-----------------|-----------|--|
| Capacity control  | —               |           |  |
| Reference temperature                                       | Dew point temp. |           |  |
| Suction gas temperature                                     | toh             | 20°C      |  |
| Power voltage   | Net             | 400V/50Hz |  |
| Coefficient of degradation for units w/o capacity control** | Cdc             | 0,25      |  |

Additional document: [Declaration of Conformity AC-503](#)

#### Contact details:

BITZER Kühlmaschinenbau GmbH  
Peter-Schaufel-Platz 1  
71065 Sindelfingen  
Deutschland  
Tel +49 (0) 70 31 932-0  
Fax +49 (0) 70 31 932-147  
E-Mail: [bitzer@bitzer.de](mailto:bitzer@bitzer.de)  
Internet: [www.bitzer.de](http://www.bitzer.de)

\* Symbols taken from english version of the Regulation 2015/1095

\*\* Since condensing units are non functional systems Cdc can not be determined by test. For this reason the default degradation coefficient Cdc (0.25) has to be applied according to EN 13215, Annex A.



## Performance Data Sheet according to EU Regulation 2015/1095

### SEPR Declaration Model: LHL5E/4CES-6Y

#### Refrigerant: R404A

| Item                              | Symbol* | Value |       | Unit  |
|-----------------------------------|---------|-------|-------|-------|
| Evaporating temperature           | t       | -10   | -35   | °C    |
| Annual electricity consumption    | Q       | 34533 | 21714 | kWh/a |
| Seasonal Energy Performance Ratio | SEPR    | 2,80  | 1,89  |       |

#### Point A: Parameters at full load and ambient temperature 32°C

|                        |                  |       |      |    |
|------------------------|------------------|-------|------|----|
| Rated cooling capacity | P <sub>A</sub>   | 15,74 | 5,52 | kW |
| Rated power input      | D <sub>A</sub>   | 7,90  | 4,01 | kW |
| Rated COP              | COP <sub>A</sub> | 1,99  | 1,38 |    |

#### Point B: Parameters at part load and ambient temperature 25°C

|                           |                  |       |      |    |
|---------------------------|------------------|-------|------|----|
| Declared cooling capacity | P <sub>B</sub>   | 17,69 | 6,34 | kW |
| Declared power input      | D <sub>B</sub>   | 7,50  | 3,95 | kW |
| Declared COP              | COP <sub>B</sub> | 2,36  | 1,61 |    |

#### Point C: Parameters at part load and ambient temperature 15°C

|                           |                  |      |      |    |
|---------------------------|------------------|------|------|----|
| Declared cooling capacity | P <sub>C</sub>   | 20,5 | 7,55 | kW |
| Declared power input      | D <sub>C</sub>   | 6,83 | 3,79 | kW |
| Declared COP              | COP <sub>C</sub> | 3,00 | 1,99 |    |

#### Point D: Parameters at part load and ambient temperature 5°C

|                           |                  |      |      |    |
|---------------------------|------------------|------|------|----|
| Declared cooling capacity | P <sub>D</sub>   | 23,3 | 8,76 | kW |
| Declared power input      | D <sub>D</sub>   | 6,03 | 3,56 | kW |
| Declared COP              | COP <sub>D</sub> | 3,87 | 2,46 |    |

#### Point E: Parameters at full load and ambient temperature 43°C (information only)

|                           |                  |       |      |    |
|---------------------------|------------------|-------|------|----|
| Declared cooling capacity | P <sub>E</sub>   | 12,67 | 4,08 | kW |
| Declared power input      | D <sub>E</sub>   | 8,40  | 4,03 | kW |
| Declared COP              | COP <sub>E</sub> | 1,51  | 1,01 |    |

#### Other items

|   |                 |           |  |
|---|-----------------|-----------|--|
| Capacity control  | —               |           |  |
| Reference temperature                                       | Dew point temp. |           |  |
| Suction gas temperature                                     | toh             | 20°C      |  |
| Power voltage   | Net             | 400V/50Hz |  |
| Coefficient of degradation for units w/o capacity control** | Cdc             | 0,25      |  |

Additional document: [Declaration of Conformity AC-503](#)

#### Contact details:

BITZER Kühlmaschinenbau GmbH  
Peter-Schaufler-Platz 1  
71065 Sindelfingen  
Deutschland  
Tel +49 (0) 70 31 932-0  
Fax +49 (0) 70 31 932-147  
E-Mail: [bitzer@bitzer.de](mailto:bitzer@bitzer.de)  
Internet: [www.bitzer.de](http://www.bitzer.de)

\* Symbols taken from english version of the Regulation 2015/1095

\*\* Since condensing units are non functional systems Cdc can not be determined by test. For this reason the default degradation coefficient Cdc (0.25) has to be applied according to EN 13215, Annex A.



## Performance Data Sheet according to EU Regulation 2015/1095

### SEPR Declaration Model: LHL5E/4CES-6Y

#### Refrigerant: R407A

| Item                              | Symbol* | Value |       | Unit  |
|-----------------------------------|---------|-------|-------|-------|
| Evaporating temperature           | t       | -10   | -35   | °C    |
| Annual electricity consumption    | Q       | 30975 | 17578 | kWh/a |
| Seasonal Energy Performance Ratio | SEPR    | 2,86  | 1,69  |       |

#### Point A: Parameters at full load and ambient temperature 32°C

|                        |                  |       |      |    |
|------------------------|------------------|-------|------|----|
| Rated cooling capacity | P <sub>A</sub>   | 14,43 | 3,98 | kW |
| Rated power input      | D <sub>A</sub>   | 6,98  | 3,20 | kW |
| Rated COP              | COP <sub>A</sub> | 2,07  | 1,24 |    |

#### Point B: Parameters at part load and ambient temperature 25°C

|                           |                  |       |      |    |
|---------------------------|------------------|-------|------|----|
| Declared cooling capacity | P <sub>B</sub>   | 16,04 | 4,59 | kW |
| Declared power input      | D <sub>B</sub>   | 6,63  | 3,19 | kW |
| Declared COP              | COP <sub>B</sub> | 2,42  | 1,44 |    |

#### Point C: Parameters at part load and ambient temperature 15°C

|                           |                  |       |      |    |
|---------------------------|------------------|-------|------|----|
| Declared cooling capacity | P <sub>C</sub>   | 18,40 | 5,48 | kW |
| Declared power input      | D <sub>C</sub>   | 6,02  | 3,12 | kW |
| Declared COP              | COP <sub>C</sub> | 3,06  | 1,76 |    |

#### Point D: Parameters at part load and ambient temperature 5°C

|                           |                  |      |      |    |
|---------------------------|------------------|------|------|----|
| Declared cooling capacity | P <sub>D</sub>   | 20,8 | 6,64 | kW |
| Declared power input      | D <sub>D</sub>   | 5,29 | 2,98 | kW |
| Declared COP              | COP <sub>D</sub> | 3,93 | 2,23 |    |

#### Point E: Parameters at full load and ambient temperature 43°C (information only)

|                           |                  |       |      |    |
|---------------------------|------------------|-------|------|----|
| Declared cooling capacity | P <sub>E</sub>   | 11,32 | 3,09 | kW |
| Declared power input      | D <sub>E</sub>   | 7,41  | 3,15 | kW |
| Declared COP              | COP <sub>E</sub> | 1,53  | 0,98 |    |

#### Other items

|   |                 |           |  |
|---|-----------------|-----------|--|
| Capacity control  | —               |           |  |
| Reference temperature                                       | Dew point temp. |           |  |
| Suction gas temperature                                     | toh             | 20°C      |  |
| Power voltage   | Net             | 400V/50Hz |  |
| Coefficient of degradation for units w/o capacity control** | Cdc             | 0,25      |  |

Additional document: [Declaration of Conformity AC-503](#)

#### Contact details:

BITZER Kühlmaschinenbau GmbH  
Peter-Schaufler-Platz 1  
71065 Sindelfingen  
Deutschland  
Tel +49 (0) 70 31 932-0  
Fax +49 (0) 70 31 932-147  
E-Mail: [bitzer@bitzer.de](mailto:bitzer@bitzer.de)  
Internet: [www.bitzer.de](http://www.bitzer.de)

\* Symbols taken from english version of the Regulation 2015/1095

\*\* Since condensing units are non functional systems Cdc can not be determined by test. For this reason the default degradation coefficient Cdc (0.25) has to be applied according to EN 13215, Annex A.



## Performance Data Sheet according to EU Regulation 2015/1095

### SEPR Declaration Model: LHL5E/4CES-6Y

#### Refrigerant: R407C

| Item                              | Symbol* | Value | Unit  |
|-----------------------------------|---------|-------|-------|
| Evaporating temperature           | t       | -10   | °C    |
| Annual electricity consumption    | Q       | 29093 | kWh/a |
| Seasonal Energy Performance Ratio | SEPR    | 2,93  |       |

#### Point A: Parameters at full load and ambient temperature 32°C

|                        |                        |             |  |    |
|------------------------|------------------------|-------------|--|----|
| Rated cooling capacity | P <sub>A</sub>         | 13,88       |  | kW |
| Rated power input      | D <sub>A</sub>         | 6,48        |  | kW |
| <b>Rated COP</b>       | <b>COP<sub>A</sub></b> | <b>2,14</b> |  |    |

#### Point B: Parameters at part load and ambient temperature 25°C

|                           |                        |             |  |    |
|---------------------------|------------------------|-------------|--|----|
| Declared cooling capacity | P <sub>B</sub>         | 15,40       |  | kW |
| Declared power input      | D <sub>B</sub>         | 6,17        |  | kW |
| <b>Declared COP</b>       | <b>COP<sub>B</sub></b> | <b>2,50</b> |  |    |

#### Point C: Parameters at part load and ambient temperature 15°C

|                           |                        |             |  |    |
|---------------------------|------------------------|-------------|--|----|
| Declared cooling capacity | P <sub>C</sub>         | 17,56       |  | kW |
| Declared power input      | D <sub>C</sub>         | 5,61        |  | kW |
| <b>Declared COP</b>       | <b>COP<sub>C</sub></b> | <b>3,13</b> |  |    |

#### Point D: Parameters at part load and ambient temperature 5°C

|                           |                        |             |  |    |
|---------------------------|------------------------|-------------|--|----|
| Declared cooling capacity | P <sub>D</sub>         | 19,72       |  | kW |
| Declared power input      | D <sub>D</sub>         | 4,93        |  | kW |
| <b>Declared COP</b>       | <b>COP<sub>D</sub></b> | <b>4,00</b> |  |    |

#### Point E: Parameters at full load and ambient temperature 43°C (information only)

|                           |                        |           |  |    |
|---------------------------|------------------------|-----------|--|----|
| Declared cooling capacity | P <sub>E</sub>         | --        |  | kW |
| Declared power input      | D <sub>E</sub>         | --        |  | kW |
| <b>Declared COP</b>       | <b>COP<sub>E</sub></b> | <b>--</b> |  |    |

#### Other items

|   |                 |           |  |
|---|-----------------|-----------|--|
| Capacity control  | —               |           |  |
| Reference temperature                                       | Dew point temp. |           |  |
| Suction gas temperature                                     | toh             | 20°C      |  |
| Power voltage   | Net             | 400V/50Hz |  |
| Coefficient of degradation for units w/o capacity control** | Cdc             | 0,25      |  |

Additional document: [Declaration of Conformity AC-503](#)

#### Contact details:

BITZER Kühlmaschinenbau GmbH  
Peter-Schaufel-Platz 1  
71065 Sindelfingen  
Deutschland  
Tel +49 (0) 70 31 932-0  
Fax +49 (0) 70 31 932-147  
E-Mail: [bitzer@bitzer.de](mailto:bitzer@bitzer.de)  
Internet: [www.bitzer.de](http://www.bitzer.de)

\* Symbols taken from english version of the Regulation 2015/1095

\*\* Since condensing units are non functional systems Cdc can not be determined by test. For this reason the default degradation coefficient Cdc (0.25) has to be applied according to EN 13215, Annex A.



## Performance Data Sheet according to EU Regulation 2015/1095

### SEPR Declaration Model: LHL5E/4CES-6Y

#### Refrigerant: R407F

| Item                              | Symbol* | Value |       | Unit  |
|-----------------------------------|---------|-------|-------|-------|
| Evaporating temperature           | t       | -10   | -35   | °C    |
| Annual electricity consumption    | Q       | 33365 | 18587 | kWh/a |
| Seasonal Energy Performance Ratio | SEPR    | 2,81  | 1,70  |       |

#### Point A: Parameters at full load and ambient temperature 32°C

|                        |                  |       |      |    |
|------------------------|------------------|-------|------|----|
| Rated cooling capacity | P <sub>A</sub>   | 15,23 | 4,24 | kW |
| Rated power input      | D <sub>A</sub>   | 7,47  | 3,39 | kW |
| Rated COP              | COP <sub>A</sub> | 2,04  | 1,25 |    |

#### Point B: Parameters at part load and ambient temperature 25°C

|                           |                  |       |      |    |
|---------------------------|------------------|-------|------|----|
| Declared cooling capacity | P <sub>B</sub>   | 16,86 | 4,87 | kW |
| Declared power input      | D <sub>B</sub>   | 7,09  | 3,37 | kW |
| Declared COP              | COP <sub>B</sub> | 2,38  | 1,44 |    |

#### Point C: Parameters at part load and ambient temperature 15°C

|                           |                  |       |      |    |
|---------------------------|------------------|-------|------|----|
| Declared cooling capacity | P <sub>C</sub>   | 19,24 | 5,79 | kW |
| Declared power input      | D <sub>C</sub>   | 6,43  | 3,29 | kW |
| Declared COP              | COP <sub>C</sub> | 2,99  | 1,76 |    |

#### Point D: Parameters at part load and ambient temperature 5°C

|                           |                  |      |      |    |
|---------------------------|------------------|------|------|----|
| Declared cooling capacity | P <sub>D</sub>   | 21,6 | 7,02 | kW |
| Declared power input      | D <sub>D</sub>   | 5,65 | 3,13 | kW |
| Declared COP              | COP <sub>D</sub> | 3,83 | 2,25 |    |

#### Point E: Parameters at full load and ambient temperature 43°C (information only)

|                           |                  |       |      |    |
|---------------------------|------------------|-------|------|----|
| Declared cooling capacity | P <sub>E</sub>   | 12,04 | 3,31 | kW |
| Declared power input      | D <sub>E</sub>   | 7,94  | 3,34 | kW |
| Declared COP              | COP <sub>E</sub> | 1,52  | 0,99 |    |

#### Other items

|   |                 |           |  |
|---|-----------------|-----------|--|
| Capacity control  | —               |           |  |
| Reference temperature                                       | Dew point temp. |           |  |
| Suction gas temperature                                     | toh             | 20°C      |  |
| Power voltage   | Net             | 400V/50Hz |  |
| Coefficient of degradation for units w/o capacity control** | Cdc             | 0,25      |  |

Additional document: [Declaration of Conformity AC-503](#)

#### Contact details:

BITZER Kühlmaschinenbau GmbH  
Peter-Schaufel-Platz 1  
71065 Sindelfingen  
Deutschland  
Tel +49 (0) 70 31 932-0  
Fax +49 (0) 70 31 932-147  
E-Mail: [bitzer@bitzer.de](mailto:bitzer@bitzer.de)  
Internet: [www.bitzer.de](http://www.bitzer.de)

\* Symbols taken from english version of the Regulation 2015/1095

\*\* Since condensing units are non functional systems Cdc can not be determined by test. For this reason the default degradation coefficient Cdc (0.25) has to be applied according to EN 13215, Annex A.



## Performance Data Sheet according to EU Regulation 2015/1095

### SEPR Declaration Model: LHL5E/4CES-6Y

#### Refrigerant: R454C

| Item                              | Symbol* | Value |       | Unit  |
|-----------------------------------|---------|-------|-------|-------|
| Evaporating temperature           | t       | -10   | -35   | °C    |
| Annual electricity consumption    | Q       | 28146 | 16902 | kWh/a |
| Seasonal Energy Performance Ratio | SEPR    | 2,96  | 1,73  |       |

#### Point A: Parameters at full load and ambient temperature 32°C

|                        |                  |       |      |    |
|------------------------|------------------|-------|------|----|
| Rated cooling capacity | P <sub>A</sub>   | 13,57 | 3,92 | kW |
| Rated power input      | D <sub>A</sub>   | 6,38  | 3,09 | kW |
| Rated COP              | COP <sub>A</sub> | 2,13  | 1,27 |    |

#### Point B: Parameters at part load and ambient temperature 25°C

|                           |                  |       |      |    |
|---------------------------|------------------|-------|------|----|
| Declared cooling capacity | P <sub>B</sub>   | 15,09 | 4,49 | kW |
| Declared power input      | D <sub>B</sub>   | 6,05  | 3,08 | kW |
| Declared COP              | COP <sub>B</sub> | 2,50  | 1,46 |    |

#### Point C: Parameters at part load and ambient temperature 15°C

|                           |                  |       |      |    |
|---------------------------|------------------|-------|------|----|
| Declared cooling capacity | P <sub>C</sub>   | 17,30 | 5,60 | kW |
| Declared power input      | D <sub>C</sub>   | 5,47  | 3,01 | kW |
| Declared COP              | COP <sub>C</sub> | 3,16  | 1,86 |    |

#### Point D: Parameters at part load and ambient temperature 5°C

|                           |                  |       |      |    |
|---------------------------|------------------|-------|------|----|
| Declared cooling capacity | P <sub>D</sub>   | 19,51 | 6,38 | kW |
| Declared power input      | D <sub>D</sub>   | 4,79  | 2,88 | kW |
| Declared COP              | COP <sub>D</sub> | 4,08  | 2,22 |    |

#### Point E: Parameters at full load and ambient temperature 43°C (information only)

|                           |                  |       |      |    |
|---------------------------|------------------|-------|------|----|
| Declared cooling capacity | P <sub>E</sub>   | 11,23 | 3,06 | kW |
| Declared power input      | D <sub>E</sub>   | 6,80  | 3,04 | kW |
| Declared COP              | COP <sub>E</sub> | 1,65  | 1,01 |    |

#### Other items

|   |                 |           |  |
|---|-----------------|-----------|--|
| Capacity control  | —               |           |  |
| Reference temperature                                       | Dew point temp. |           |  |
| Suction gas temperature                                     | toh             | 20°C      |  |
| Power voltage   | Net             | 400V/50Hz |  |
| Coefficient of degradation for units w/o capacity control** | Cdc             | 0,25      |  |

Additional document: [Declaration of Conformity AC-503](#)

#### Contact details:

BITZER Kühlmaschinenbau GmbH  
Peter-Schaufler-Platz 1  
71065 Sindelfingen  
Deutschland  
Tel +49 (0) 70 31 932-0  
Fax +49 (0) 70 31 932-147  
E-Mail: [bitzer@bitzer.de](mailto:bitzer@bitzer.de)  
Internet: [www.bitzer.de](http://www.bitzer.de)

\* Symbols taken from english version of the Regulation 2015/1095

\*\* Since condensing units are non functional systems Cdc can not be determined by test. For this reason the default degradation coefficient Cdc (0.25) has to be applied according to EN 13215, Annex A.



## Performance Data Sheet according to EU Regulation 2015/1095

### SEPR Declaration Model: LHL5E/4CES-6Y

#### Refrigerant: R455A

| Item                              | Symbol* | Value |       | Unit  |
|-----------------------------------|---------|-------|-------|-------|
| Evaporating temperature           | t       | -10   | -35   | °C    |
| Annual electricity consumption    | Q       | 31358 | 17902 | kWh/a |
| Seasonal Energy Performance Ratio | SEPR    | 2,61  | 1,58  |       |

#### Point A: Parameters at full load and ambient temperature 32°C

|                        |                  |       |      |    |
|------------------------|------------------|-------|------|----|
| Rated cooling capacity | P <sub>A</sub>   | 13,30 | 3,79 | kW |
| Rated power input      | D <sub>A</sub>   | 7,02  | 3,26 | kW |
| Rated COP              | COP <sub>A</sub> | 1,90  | 1,16 |    |

#### Point B: Parameters at part load and ambient temperature 25°C

|                           |                  |       |      |    |
|---------------------------|------------------|-------|------|----|
| Declared cooling capacity | P <sub>B</sub>   | 14,89 | 4,39 | kW |
| Declared power input      | D <sub>B</sub>   | 6,70  | 3,27 | kW |
| Declared COP              | COP <sub>B</sub> | 2,22  | 1,34 |    |

#### Point C: Parameters at part load and ambient temperature 15°C

|                           |                  |       |      |    |
|---------------------------|------------------|-------|------|----|
| Declared cooling capacity | P <sub>C</sub>   | 17,20 | 5,28 | kW |
| Declared power input      | D <sub>C</sub>   | 6,15  | 3,22 | kW |
| Declared COP              | COP <sub>C</sub> | 2,80  | 1,64 |    |

#### Point D: Parameters at part load and ambient temperature 5°C

|                           |                  |       |      |    |
|---------------------------|------------------|-------|------|----|
| Declared cooling capacity | P <sub>D</sub>   | 19,55 | 6,49 | kW |
| Declared power input      | D <sub>D</sub>   | 5,49  | 3,10 | kW |
| Declared COP              | COP <sub>D</sub> | 3,56  | 2,09 |    |

#### Point E: Parameters at full load and ambient temperature 43°C (information only)

|                           |                  |    |    |    |
|---------------------------|------------------|----|----|----|
| Declared cooling capacity | P <sub>E</sub>   | -- | -- | kW |
| Declared power input      | D <sub>E</sub>   | -- | -- | kW |
| Declared COP              | COP <sub>E</sub> | -- | -- |    |

#### Other items

|   |                 |           |  |
|---|-----------------|-----------|--|
| Capacity control  | —               |           |  |
| Reference temperature                                       | Dew point temp. |           |  |
| Suction gas temperature                                     | toh             | 20°C      |  |
| Power voltage   | Net             | 400V/50Hz |  |
| Coefficient of degradation for units w/o capacity control** | Cdc             | 0,25      |  |

Additional document: [Declaration of Conformity AC-503](#)

#### Contact details:

BITZER Kühlmaschinenbau GmbH  
Peter-Schaufel-Platz 1  
71065 Sindelfingen  
Deutschland  
Tel +49 (0) 70 31 932-0  
Fax +49 (0) 70 31 932-147  
E-Mail: [bitzer@bitzer.de](mailto:bitzer@bitzer.de)  
Internet: [www.bitzer.de](http://www.bitzer.de)

\* Symbols taken from english version of the Regulation 2015/1095

\*\* Since condensing units are non functional systems Cdc can not be determined by test. For this reason the default degradation coefficient Cdc (0.25) has to be applied according to EN 13215, Annex A.



## Performance Data Sheet according to EU Regulation 2015/1095

### SEPR Declaration Model: LHL5E/4CES-6Y

#### Refrigerant: R507A

| Item                              | Symbol* | Value |       | Unit  |
|-----------------------------------|---------|-------|-------|-------|
| Evaporating temperature           | t       | -10   | -35   | °C    |
| Annual electricity consumption    | Q       | 34611 | 21748 | kWh/a |
| Seasonal Energy Performance Ratio | SEPR    | 2,85  | 1,98  |       |

#### Point A: Parameters at full load and ambient temperature 32°C

|                        |                  |       |      |    |
|------------------------|------------------|-------|------|----|
| Rated cooling capacity | P <sub>A</sub>   | 16,07 | 5,76 | kW |
| Rated power input      | D <sub>A</sub>   | 7,91  | 4,01 | kW |
| Rated COP              | COP <sub>A</sub> | 2,03  | 1,44 |    |

#### Point B: Parameters at part load and ambient temperature 25°C

|                           |                  |       |      |    |
|---------------------------|------------------|-------|------|----|
| Declared cooling capacity | P <sub>B</sub>   | 18,09 | 6,62 | kW |
| Declared power input      | D <sub>B</sub>   | 7,52  | 3,95 | kW |
| Declared COP              | COP <sub>B</sub> | 2,40  | 1,68 |    |

#### Point C: Parameters at part load and ambient temperature 15°C

|                           |                  |      |      |    |
|---------------------------|------------------|------|------|----|
| Declared cooling capacity | P <sub>C</sub>   | 21,0 | 7,89 | kW |
| Declared power input      | D <sub>C</sub>   | 6,86 | 3,80 | kW |
| Declared COP              | COP <sub>C</sub> | 3,06 | 2,08 |    |

#### Point D: Parameters at part load and ambient temperature 5°C

|                           |                  |      |      |    |
|---------------------------|------------------|------|------|----|
| Declared cooling capacity | P <sub>D</sub>   | 23,9 | 9,16 | kW |
| Declared power input      | D <sub>D</sub>   | 6,08 | 3,57 | kW |
| Declared COP              | COP <sub>D</sub> | 3,94 | 2,57 |    |

#### Point E: Parameters at full load and ambient temperature 43°C (information only)

|                           |                  |       |      |    |
|---------------------------|------------------|-------|------|----|
| Declared cooling capacity | P <sub>E</sub>   | 12,83 | 4,26 | kW |
| Declared power input      | D <sub>E</sub>   | 8,41  | 4,04 | kW |
| Declared COP              | COP <sub>E</sub> | 1,53  | 1,06 |    |

#### Other items

|   |                 |           |  |
|---|-----------------|-----------|--|
| Capacity control  | —               |           |  |
| Reference temperature                                       | Dew point temp. |           |  |
| Suction gas temperature                                     | toh             | 20°C      |  |
| Power voltage   | Net             | 400V/50Hz |  |
| Coefficient of degradation for units w/o capacity control** | Cdc             | 0,25      |  |

Additional document: [Declaration of Conformity AC-503](#)

#### Contact details:

BITZER Kühlmaschinenbau GmbH  
Peter-Schaufler-Platz 1  
71065 Sindelfingen  
Deutschland  
Tel +49 (0) 70 31 932-0  
Fax +49 (0) 70 31 932-147  
E-Mail: [bitzer@bitzer.de](mailto:bitzer@bitzer.de)  
Internet: [www.bitzer.de](http://www.bitzer.de)

\* Symbols taken from english version of the Regulation 2015/1095

\*\* Since condensing units are non functional systems Cdc can not be determined by test. For this reason the default degradation coefficient Cdc (0.25) has to be applied according to EN 13215, Annex A.



## Performance Data Sheet according to EU Regulation 2015/1095

### SEPR Declaration Model: LHL5E/4CES-6Y

#### Refrigerant: R448A

| Item                              | Symbol* | Value |       | Unit  |
|-----------------------------------|---------|-------|-------|-------|
| Evaporating temperature           | t       | -10   | -35   | °C    |
| Annual electricity consumption    | Q       | 32178 | 18364 | kWh/a |
| Seasonal Energy Performance Ratio | SEPR    | 2,84  | 1,74  |       |

#### Point A: Parameters at full load and ambient temperature 32°C

|                        |                  |       |      |    |
|------------------------|------------------|-------|------|----|
| Rated cooling capacity | P <sub>A</sub>   | 14,87 | 4,28 | kW |
| Rated power input      | D <sub>A</sub>   | 7,26  | 3,40 | kW |
| Rated COP              | COP <sub>A</sub> | 2,05  | 1,26 |    |

#### Point B: Parameters at part load and ambient temperature 25°C

|                           |                  |       |      |    |
|---------------------------|------------------|-------|------|----|
| Declared cooling capacity | P <sub>B</sub>   | 16,52 | 4,91 | kW |
| Declared power input      | D <sub>B</sub>   | 6,88  | 3,39 | kW |
| Declared COP              | COP <sub>B</sub> | 2,40  | 1,45 |    |

#### Point C: Parameters at part load and ambient temperature 15°C

|                           |                  |       |      |    |
|---------------------------|------------------|-------|------|----|
| Declared cooling capacity | P <sub>C</sub>   | 18,91 | 6,15 | kW |
| Declared power input      | D <sub>C</sub>   | 6,24  | 3,30 | kW |
| Declared COP              | COP <sub>C</sub> | 3,03  | 1,86 |    |

#### Point D: Parameters at part load and ambient temperature 5°C

|                           |                  |      |      |    |
|---------------------------|------------------|------|------|----|
| Declared cooling capacity | P <sub>D</sub>   | 21,3 | 7,08 | kW |
| Declared power input      | D <sub>D</sub>   | 5,47 | 3,14 | kW |
| Declared COP              | COP <sub>D</sub> | 3,89 | 2,25 |    |

#### Point E: Parameters at full load and ambient temperature 43°C (information only)

|                           |                  |       |      |    |
|---------------------------|------------------|-------|------|----|
| Declared cooling capacity | P <sub>E</sub>   | 12,31 | 3,34 | kW |
| Declared power input      | D <sub>E</sub>   | 7,72  | 3,36 | kW |
| Declared COP              | COP <sub>E</sub> | 1,59  | 1,00 |    |

#### Other items

|   |                 |           |  |
|---|-----------------|-----------|--|
| Capacity control  | —               |           |  |
| Reference temperature                                       | Dew point temp. |           |  |
| Suction gas temperature                                     | toh             | 20°C      |  |
| Power voltage   | Net             | 400V/50Hz |  |
| Coefficient of degradation for units w/o capacity control** | Cdc             | 0,25      |  |

Additional document: [Declaration of Conformity AC-503](#)

#### Contact details:

BITZER Kühlmaschinenbau GmbH  
Peter-Schaufel-Platz 1  
71065 Sindelfingen  
Deutschland  
Tel +49 (0) 70 31 932-0  
Fax +49 (0) 70 31 932-147  
E-Mail: [bitzer@bitzer.de](mailto:bitzer@bitzer.de)  
Internet: [www.bitzer.de](http://www.bitzer.de)

\* Symbols taken from english version of the Regulation 2015/1095

\*\* Since condensing units are non functional systems Cdc can not be determined by test. For this reason the default degradation coefficient Cdc (0.25) has to be applied according to EN 13215, Annex A.



## Performance Data Sheet according to EU Regulation 2015/1095

### SEPR Declaration Model: LHL5E/4CES-6Y

#### Refrigerant: R449A

| Item                              | Symbol* | Value |       | Unit  |
|-----------------------------------|---------|-------|-------|-------|
| Evaporating temperature           | t       | -10   | -35   | °C    |
| Annual electricity consumption    | Q       | 32120 | 18352 | kWh/a |
| Seasonal Energy Performance Ratio | SEPR    | 2,83  | 1,73  |       |

#### Point A: Parameters at full load and ambient temperature 32°C

|                        |                  |       |      |    |
|------------------------|------------------|-------|------|----|
| Rated cooling capacity | P <sub>A</sub>   | 14,80 | 4,27 | kW |
| Rated power input      | D <sub>A</sub>   | 7,26  | 3,40 | kW |
| Rated COP              | COP <sub>A</sub> | 2,04  | 1,26 |    |

#### Point B: Parameters at part load and ambient temperature 25°C

|                           |                  |       |      |    |
|---------------------------|------------------|-------|------|----|
| Declared cooling capacity | P <sub>B</sub>   | 16,45 | 4,91 | kW |
| Declared power input      | D <sub>B</sub>   | 6,88  | 3,39 | kW |
| Declared COP              | COP <sub>B</sub> | 2,39  | 1,45 |    |

#### Point C: Parameters at part load and ambient temperature 15°C

|                           |                  |       |      |    |
|---------------------------|------------------|-------|------|----|
| Declared cooling capacity | P <sub>C</sub>   | 18,84 | 6,15 | kW |
| Declared power input      | D <sub>C</sub>   | 6,24  | 3,30 | kW |
| Declared COP              | COP <sub>C</sub> | 3,02  | 1,86 |    |

#### Point D: Parameters at part load and ambient temperature 5°C

|                           |                  |      |      |    |
|---------------------------|------------------|------|------|----|
| Declared cooling capacity | P <sub>D</sub>   | 21,3 | 7,08 | kW |
| Declared power input      | D <sub>D</sub>   | 5,47 | 3,14 | kW |
| Declared COP              | COP <sub>D</sub> | 3,89 | 2,25 |    |

#### Point E: Parameters at full load and ambient temperature 43°C (information only)

|                           |                  |       |      |    |
|---------------------------|------------------|-------|------|----|
| Declared cooling capacity | P <sub>E</sub>   | 12,24 | 3,34 | kW |
| Declared power input      | D <sub>E</sub>   | 7,72  | 3,36 | kW |
| Declared COP              | COP <sub>E</sub> | 1,59  | 0,99 |    |

#### Other items

|   |                 |           |  |
|---|-----------------|-----------|--|
| Capacity control  | —               |           |  |
| Reference temperature                                       | Dew point temp. |           |  |
| Suction gas temperature                                     | toh             | 20°C      |  |
| Power voltage   | Net             | 400V/50Hz |  |
| Coefficient of degradation for units w/o capacity control** | Cdc             | 0,25      |  |

Additional document: [Declaration of Conformity AC-503](#)

#### Contact details:

BITZER Kühlmaschinenbau GmbH  
Peter-Schaufel-Platz 1  
71065 Sindelfingen  
Deutschland  
Tel +49 (0) 70 31 932-0  
Fax +49 (0) 70 31 932-147  
E-Mail: [bitzer@bitzer.de](mailto:bitzer@bitzer.de)  
Internet: [www.bitzer.de](http://www.bitzer.de)

\* Symbols taken from english version of the Regulation 2015/1095

\*\* Since condensing units are non functional systems Cdc can not be determined by test. For this reason the default degradation coefficient Cdc (0.25) has to be applied according to EN 13215, Annex A.



## Performance Data Sheet according to EU Regulation 2015/1095

### SEPR Declaration Model: LHL5E/4CES-6Y

#### Refrigerant: R450A

| Item                              | Symbol* | Value | Unit  |
|-----------------------------------|---------|-------|-------|
| Evaporating temperature           | t       | -10   | °C    |
| Annual electricity consumption    | Q       | 15857 | kWh/a |
| Seasonal Energy Performance Ratio | SEPR    | 3,49  |       |

#### Point A: Parameters at full load and ambient temperature 32°C

|                        |                        |             |  |    |
|------------------------|------------------------|-------------|--|----|
| Rated cooling capacity | P <sub>A</sub>         | 9,01        |  | kW |
| Rated power input      | D <sub>A</sub>         | 3,63        |  | kW |
| <b>Rated COP</b>       | <b>COP<sub>A</sub></b> | <b>2,48</b> |  |    |

#### Point B: Parameters at part load and ambient temperature 25°C

|                           |                        |             |  |    |
|---------------------------|------------------------|-------------|--|----|
| Declared cooling capacity | P <sub>B</sub>         | 9,90        |  | kW |
| Declared power input      | D <sub>B</sub>         | 3,40        |  | kW |
| <b>Declared COP</b>       | <b>COP<sub>B</sub></b> | <b>2,91</b> |  |    |

#### Point C: Parameters at part load and ambient temperature 15°C

|                           |                        |             |  |    |
|---------------------------|------------------------|-------------|--|----|
| Declared cooling capacity | P <sub>C</sub>         | 11,15       |  | kW |
| Declared power input      | D <sub>C</sub>         | 3,02        |  | kW |
| <b>Declared COP</b>       | <b>COP<sub>C</sub></b> | <b>3,70</b> |  |    |

#### Point D: Parameters at part load and ambient temperature 5°C

|                           |                        |             |  |    |
|---------------------------|------------------------|-------------|--|----|
| Declared cooling capacity | P <sub>D</sub>         | 12,40       |  | kW |
| Declared power input      | D <sub>D</sub>         | 2,57        |  | kW |
| <b>Declared COP</b>       | <b>COP<sub>D</sub></b> | <b>4,82</b> |  |    |

#### Point E: Parameters at full load and ambient temperature 43°C (information only)

|                           |                        |             |  |    |
|---------------------------|------------------------|-------------|--|----|
| Declared cooling capacity | P <sub>E</sub>         | 7,63        |  | kW |
| Declared power input      | D <sub>E</sub>         | 3,91        |  | kW |
| <b>Declared COP</b>       | <b>COP<sub>E</sub></b> | <b>1,95</b> |  |    |

#### Other items

|   |                 |           |  |
|---|-----------------|-----------|--|
| Capacity control  | —               |           |  |
| Reference temperature                                       | Dew point temp. |           |  |
| Suction gas temperature                                     | toh             | 20°C      |  |
| Power voltage   | Net             | 400V/50Hz |  |
| Coefficient of degradation for units w/o capacity control** | Cdc             | 0,25      |  |

Additional document: [Declaration of Conformity AC-503](#)

#### Contact details:

BITZER Kühlmaschinenbau GmbH  
Peter-Schaufler-Platz 1  
71065 Sindelfingen  
Deutschland  
Tel +49 (0) 70 31 932-0  
Fax +49 (0) 70 31 932-147  
E-Mail: [bitzer@bitzer.de](mailto:bitzer@bitzer.de)  
Internet: [www.bitzer.de](http://www.bitzer.de)

\* Symbols taken from english version of the Regulation 2015/1095

\*\* Since condensing units are non functional systems Cdc can not be determined by test. For this reason the default degradation coefficient Cdc (0.25) has to be applied according to EN 13215, Annex A.



## Performance Data Sheet according to EU Regulation 2015/1095

### SEPR Declaration Model: LHL5E/4CES-6Y

#### Refrigerant: R513A

| Item                              | Symbol* | Value | Unit  |
|-----------------------------------|---------|-------|-------|
| Evaporating temperature           | t       | -10   | °C    |
| Annual electricity consumption    | Q       | 19014 | kWh/a |
| Seasonal Energy Performance Ratio | SEPR    | 3,47  |       |

#### Point A: Parameters at full load and ambient temperature 32°C

|                        |                        |             |  |    |
|------------------------|------------------------|-------------|--|----|
| Rated cooling capacity | P <sub>A</sub>         | 10,74       |  | kW |
| Rated power input      | D <sub>A</sub>         | 4,35        |  | kW |
| <b>Rated COP</b>       | <b>COP<sub>A</sub></b> | <b>2,47</b> |  |    |

#### Point B: Parameters at part load and ambient temperature 25°C

|                           |                        |             |  |    |
|---------------------------|------------------------|-------------|--|----|
| Declared cooling capacity | P <sub>B</sub>         | 11,85       |  | kW |
| Declared power input      | D <sub>B</sub>         | 4,09        |  | kW |
| <b>Declared COP</b>       | <b>COP<sub>B</sub></b> | <b>2,90</b> |  |    |

#### Point C: Parameters at part load and ambient temperature 15°C

|                           |                        |             |  |    |
|---------------------------|------------------------|-------------|--|----|
| Declared cooling capacity | P <sub>C</sub>         | 13,41       |  | kW |
| Declared power input      | D <sub>C</sub>         | 3,65        |  | kW |
| <b>Declared COP</b>       | <b>COP<sub>C</sub></b> | <b>3,68</b> |  |    |

#### Point D: Parameters at part load and ambient temperature 5°C

|                           |                        |             |  |    |
|---------------------------|------------------------|-------------|--|----|
| Declared cooling capacity | P <sub>D</sub>         | 14,96       |  | kW |
| Declared power input      | D <sub>D</sub>         | 3,12        |  | kW |
| <b>Declared COP</b>       | <b>COP<sub>D</sub></b> | <b>4,79</b> |  |    |

#### Point E: Parameters at full load and ambient temperature 43°C (information only)

|                           |                        |             |  |    |
|---------------------------|------------------------|-------------|--|----|
| Declared cooling capacity | P <sub>E</sub>         | 8,99        |  | kW |
| Declared power input      | D <sub>E</sub>         | 4,66        |  | kW |
| <b>Declared COP</b>       | <b>COP<sub>E</sub></b> | <b>1,93</b> |  |    |

#### Other items

|   |                 |           |  |
|---|-----------------|-----------|--|
| Capacity control  | —               |           |  |
| Reference temperature                                       | Dew point temp. |           |  |
| Suction gas temperature                                     | toh             | 20°C      |  |
| Power voltage   | Net             | 400V/50Hz |  |
| Coefficient of degradation for units w/o capacity control** | Cdc             | 0,25      |  |

Additional document: [Declaration of Conformity AC-503](#)

#### Contact details:

BITZER Kühlmaschinenbau GmbH  
Peter-Schaufel-Platz 1  
71065 Sindelfingen  
Deutschland  
Tel +49 (0) 70 31 932-0  
Fax +49 (0) 70 31 932-147  
E-Mail: [bitzer@bitzer.de](mailto:bitzer@bitzer.de)  
Internet: [www.bitzer.de](http://www.bitzer.de)

\* Symbols taken from english version of the Regulation 2015/1095

\*\* Since condensing units are non functional systems Cdc can not be determined by test. For this reason the default degradation coefficient Cdc (0.25) has to be applied according to EN 13215, Annex A.



## Performance Data Sheet according to EU Regulation 2015/1095

### SEPR Declaration Model: LHL5E/4CES-6Y

Refrigerant: R1234yf

| Item                              | Symbol* | Value | Unit  |
|-----------------------------------|---------|-------|-------|
| Evaporating temperature           | t       | -10   | °C    |
| Annual electricity consumption    | Q       | 18335 | kWh/a |
| Seasonal Energy Performance Ratio | SEPR    | 3,47  |       |

#### Point A: Parameters at full load and ambient temperature 32°C

|                        |                        |             |  |    |
|------------------------|------------------------|-------------|--|----|
| Rated cooling capacity | P <sub>A</sub>         | 10,35       |  | kW |
| Rated power input      | D <sub>A</sub>         | 4,25        |  | kW |
| <b>Rated COP</b>       | <b>COP<sub>A</sub></b> | <b>2,44</b> |  |    |

#### Point B: Parameters at part load and ambient temperature 25°C

|                           |                        |             |  |    |
|---------------------------|------------------------|-------------|--|----|
| Declared cooling capacity | P <sub>B</sub>         | 11,45       |  | kW |
| Declared power input      | D <sub>B</sub>         | 3,98        |  | kW |
| <b>Declared COP</b>       | <b>COP<sub>B</sub></b> | <b>2,87</b> |  |    |

#### Point C: Parameters at part load and ambient temperature 15°C

|                           |                        |             |  |    |
|---------------------------|------------------------|-------------|--|----|
| Declared cooling capacity | P <sub>C</sub>         | 13,02       |  | kW |
| Declared power input      | D <sub>C</sub>         | 3,54        |  | kW |
| <b>Declared COP</b>       | <b>COP<sub>C</sub></b> | <b>3,68</b> |  |    |

#### Point D: Parameters at part load and ambient temperature 5°C

|                           |                        |             |  |    |
|---------------------------|------------------------|-------------|--|----|
| Declared cooling capacity | P <sub>D</sub>         | 14,59       |  | kW |
| Declared power input      | D <sub>D</sub>         | 3,02        |  | kW |
| <b>Declared COP</b>       | <b>COP<sub>D</sub></b> | <b>4,82</b> |  |    |

#### Point E: Parameters at full load and ambient temperature 43°C (information only)

|                           |                        |             |  |    |
|---------------------------|------------------------|-------------|--|----|
| Declared cooling capacity | P <sub>E</sub>         | 8,64        |  | kW |
| Declared power input      | D <sub>E</sub>         | 4,58        |  | kW |
| <b>Declared COP</b>       | <b>COP<sub>E</sub></b> | <b>1,88</b> |  |    |

#### Other items

|   |                 |           |  |
|---|-----------------|-----------|--|
| Capacity control  | —               |           |  |
| Reference temperature                                       | Dew point temp. |           |  |
| Suction gas temperature                                     | toh             | 20°C      |  |
| Power voltage   | Net             | 400V/50Hz |  |
| Coefficient of degradation for units w/o capacity control** | Cdc             | 0,25      |  |

Additional document: [Declaration of Conformity AC-503](#)

#### Contact details:

BITZER Kühlmaschinenbau GmbH  
Peter-Schaufel-Platz 1  
71065 Sindelfingen  
Deutschland  
Tel +49 (0) 70 31 932-0  
Fax +49 (0) 70 31 932-147  
E-Mail: [bitzer@bitzer.de](mailto:bitzer@bitzer.de)  
Internet: [www.bitzer.de](http://www.bitzer.de)

\* Symbols taken from english version of the Regulation 2015/1095

\*\* Since condensing units are non functional systems Cdc can not be determined by test. For this reason the default degradation coefficient Cdc (0.25) has to be applied according to EN 13215, Annex A.



## Performance Data Sheet according to EU Regulation 2015/1095

### SEPR Declaration Model: LHL5E/4CES-6Y

#### Refrigerant: R1234ze

| Item                              | Symbol* | Value | Unit  |
|-----------------------------------|---------|-------|-------|
| Evaporating temperature           | t       | -10   | °C    |
| Annual electricity consumption    | Q       | 13913 | kWh/a |
| Seasonal Energy Performance Ratio | SEPR    | 3,48  |       |

#### Point A: Parameters at full load and ambient temperature 32°C

|                        |                        |             |  |    |
|------------------------|------------------------|-------------|--|----|
| Rated cooling capacity | P <sub>A</sub>         | 7,87        |  | kW |
| Rated power input      | D <sub>A</sub>         | 3,11        |  | kW |
| <b>Rated COP</b>       | <b>COP<sub>A</sub></b> | <b>2,53</b> |  |    |

#### Point B: Parameters at part load and ambient temperature 25°C

|                           |                        |             |  |    |
|---------------------------|------------------------|-------------|--|----|
| Declared cooling capacity | P <sub>B</sub>         | 8,60        |  | kW |
| Declared power input      | D <sub>B</sub>         | 2,91        |  | kW |
| <b>Declared COP</b>       | <b>COP<sub>B</sub></b> | <b>2,96</b> |  |    |

#### Point C: Parameters at part load and ambient temperature 15°C

|                           |                        |             |  |    |
|---------------------------|------------------------|-------------|--|----|
| Declared cooling capacity | P <sub>C</sub>         | 9,64        |  | kW |
| Declared power input      | D <sub>C</sub>         | 2,58        |  | kW |
| <b>Declared COP</b>       | <b>COP<sub>C</sub></b> | <b>3,74</b> |  |    |

#### Point D: Parameters at part load and ambient temperature 5°C

|                           |                        |             |  |    |
|---------------------------|------------------------|-------------|--|----|
| Declared cooling capacity | P <sub>D</sub>         | 10,50       |  | kW |
| Declared power input      | D <sub>D</sub>         | 2,27        |  | kW |
| <b>Declared COP</b>       | <b>COP<sub>D</sub></b> | <b>4,63</b> |  |    |

#### Point E: Parameters at full load and ambient temperature 43°C (information only)

|                           |                        |             |  |    |
|---------------------------|------------------------|-------------|--|----|
| Declared cooling capacity | P <sub>E</sub>         | 6,72        |  | kW |
| Declared power input      | D <sub>E</sub>         | 3,37        |  | kW |
| <b>Declared COP</b>       | <b>COP<sub>E</sub></b> | <b>2,00</b> |  |    |

#### Other items

|   |                 |           |  |
|---|-----------------|-----------|--|
| Capacity control  | —               |           |  |
| Reference temperature                                       | Dew point temp. |           |  |
| Suction gas temperature                                     | toh             | 20°C      |  |
| Power voltage   | Net             | 400V/50Hz |  |
| Coefficient of degradation for units w/o capacity control** | Cdc             | 0,25      |  |

Additional document: [Declaration of Conformity AC-503](#)

#### Contact details:

BITZER Kühlmaschinenbau GmbH  
Peter-Schaufler-Platz 1  
71065 Sindelfingen  
Deutschland  
Tel +49 (0) 70 31 932-0  
Fax +49 (0) 70 31 932-147  
E-Mail: [bitzer@bitzer.de](mailto:bitzer@bitzer.de)  
Internet: [www.bitzer.de](http://www.bitzer.de)

\* Symbols taken from english version of the Regulation 2015/1095

\*\* Since condensing units are non functional systems Cdc can not be determined by test. For this reason the default degradation coefficient Cdc (0.25) has to be applied according to EN 13215, Annex A.